Correction Request Response

Houtchens Residence
9-17-24

Site address: 6024 SE 22nd St
Permit: **2209-088**

This submittal is in response to a request by Mark Jung for a correction item related to the fire sprinkler permit associated with this project (2408-007). It was requested that we update/submit our plan set to specify the requirement for the appropriate heating in our garage and basement spaces per NFPA 13R section 5.4.2 (2019). Please see updated sheets A3 and A6 of the plan set. New notes are bubbled.

This submittal includes the following:
Houtchens_PLAN SET_REV1_SUB3.pdf
Houtchens_NARRATIVE_REV1_SUB3.pdf

Thank you,

Matthew Mawer