

From: [Carolyn Decker](#)
To: [Lillian G. Heng](#)
Subject: RE: Site Retaining Walls (Project No. T-8718)
Date: Monday, June 23, 2025 11:34:27 AM
Attachments: [image001.png](#)
[image002.png](#)
[image003.png](#)
[image004.png](#)
[image005.png](#)
[image006.png](#)

CAUTION: External sender. Think before you link!

Hi Lillian,

No, they don't.

Carolyn S. Decker, P.E.

President

TERRA ASSOCIATES, INC.

12220 113th Avenue NE, Suite 130

Kirkland, Washington 98034

Office - 425-821-7777, Ext 103

Cell - 206-255-4988


cdecker@terra-associates.com

www.terra-associates.com

From: Lillian G. Heng <lheng@mulhernkulp.com>
Sent: Monday, June 23, 2025 10:58 AM
To: Carolyn Decker <CDecker@terra-associates.com>
Subject: Site Retaining Walls (Project No. T-8718)

Hi Carolyn,

I had a quick question about some additional site retaining walls that want to be added to the project listed above. The site retaining walls will be supporting about 4-5' of unbalanced fill. This will be located adjacent to the garage, see snip below. Do these site retaining walls need to be supported by pipe piles?



Best,



LILLIAN G. HENG, P.E.
Project Engineer II
619-650-0010 x194 | mulhernkulp.com

