

January 8, 2025

COMMENT RESPONSE LETTER

RE: 2401-129
5330 LANSDOWNE LANE

1. A smoke detector was added to the office above the garage
2. A fire rated door was added to the crawlspace access.

Regards,

Dave Buck, architect