

Dear Mrs. Marich,

Thank you for your comments. Your concern is one that is also shared by Mr. Leavitt, with whom I've spoken on multiple occasions. I've also discussed this matter in detail with my civil engineer.

As outlined in the latest report from my civil engineer: "*All impervious runoff from the proposed development will be collected and directed to a new storm connection within the existing conveyance system on SE 27th Street. **The existing 6-inch storm line running through the site will be capped, abandoned, and rerouted to the new storm system.***"

I believe this update to the Downstream Analysis Report should address and resolve the issue. Please let me know if you have any further questions or concerns.

Sincerely,

Tony Chen