



Cobalt Geosciences, LLC
P.O. Box 1792
North Bend, WA 98045

October 25, 2024

John Magcawas
john@sturmanarchitects.com

RE: Geotechnical Addendum
Proposed Additions
8413 SE 82nd Street
Mercer Island, Washington

In accordance with your authorization, Cobalt Geosciences, LLC has prepared this letter to discuss localized tree removal near the driveway and existing block walls.

We visited the site in October 2024 to observe the specific area. Roots of two trees near the block walls are causing structural damage and movement of the wall system. These trees may be removed without adversely affecting geologic hazards in the area or adjacent areas provided surfaces are surfaced with topsoil/mulch and new low-lying vegetation. All bare soils must be landscaped and surfaced upon completion of the removal.

Once removed, it appears that some minor wall mitigation will be necessary (block replacement/realignment). We can provide additional input upon request.

Sincerely,

Cobalt Geosciences, LLC



10/25/2024
Phil Haberman, PE, LG, LEG
Principal