



**PROJECT DESCRIPTION**  
 This scope should match the Building Permit Application Form

**PROJECT CONTACT INFORMATION**  
 The Applicant shall provide the following information for each type of contact (Engineer and Geotech dependent on scope)

Permitting Contact:	Email:	Phone:
Construction Contact:	Email:	Phone:
Engineer:	Email:	Phone:
Geotech:	Email:	Phone:

**DEFERRED SUBMITTALS**  
 The Applicant is required to indicate all deferred submittals / shop drawings for submittal to the City for review and approval prior to item fabrication / construction. All deferred submittals require pre-approval from the City during the permit review process.

No Deferred Submittals - all design included in these construction documents

Connector plate wood roof trusses  
 Metal joist / metal trusses  
 Premanufactured structures (stairs, etc.)

Exterior cladding  
 Window wall / curtain wall construction  
 Other:

**ENERGY CODE AND WHOLE HOUSE VENTILATION INFORMATION**  
 Indicate where the following information is located within the drawing set and select one box per line below.

**Building Envelope**- Define all components of the thermal envelope. Include U-factors, insulation and moisture control WSEC Table 402.1.2 Sheet: \_\_\_\_\_

**Energy Credit Information**- Include complete information on plan for options selected and equipment specified WSEC Tables 406.2 and 406.3 Sheet: \_\_\_\_\_

No Credits Required  Small Dwelling Unit  Medium Dwelling Unit  Large Dwelling Unit  < 500 sf addition

**New Construction Tests**- The following are mandatory testing and reporting requirements of WSEC Ch 4 for new construction

- Certificate of Energy Efficiency WSEC 402.3
- Duct Leakage Testing WSEC 402.3.5
- Air Leakage Testing WSEC 402.4.3.2
- Air Leakage test report not to exceed 5 changes per hour WSEC 1505.4.1.2
- Air Leakage per selected energy credits

**Whole House Ventilation**- Specify system type below and include all system requirements on sheet noted WSEC Section M1505.4 Sheet: \_\_\_\_\_

Exhaust fans WSEC 1505.4.1.2  Supply fans WSEC 1505.4.1.3  Balanced system WSEC 1505.4.1.4  Other permitted system

**REQUIRED SPECIAL INSPECTIONS**  
 The Applicant shall complete the following section. One of the options below must be selected prior to permit intake. Chapter 17 of the International Building Code (IBC) requires Special Inspection to evaluate components of construction that are critical to the safety of the structure. The project owner shall be responsible for contracting with and hiring the Special Inspection agents. Structural Special Inspectors are required to be certified by the Washington Association of Building Officials (WABO). Geotechnical Special Inspectors shall be a licensed Washington State Professional Engineer. Where Special Inspection is required, all reports shall be emailed to InspectionReports@mercergov.org and provided to the City Building Inspector at time of the City inspection.

Inspections by the City Building Inspector are required in addition to the Special Inspection.  
**Do not cover or conceal any work prior to the City inspection.**

**PRESCRIPTIVE DESIGN**  
 This project is entirely non-structural, or is designed following the prescriptive gravity and lateral provisions of the International Residential Code (IRC) only. There are no engineered components that have been designed to the IRC or its referenced standards, e.g. American Concrete Institute (ACI), National Design Specifications (NDS), etc. No Special Inspections are required by IRC.

**MINOR STRUCTURAL WORK**  
 This project has limited engineered design as permitted by IRC Section R301.1.3 and the construction is of a minor nature as excepted by IBC Section 1704.2. This option must be reviewed and accepted by the building official prior to permit issuance and shall be reevaluated for project revisions and deferred submittals.

**ENGINEERED DESIGN**  
 This project is engineered to the provisions of the IBC and its referenced standards. Per IBC Chapter 17, a *Statement of Special Inspection* shall be completed by the Registered Design Professional (RDP) in responsible charge. The *Statement of Special Inspections* on coversheet SF2 has been reviewed and completed by the RDP.

**REQUIRED STRUCTURAL OBSERVATION**  
*Structural Observation* may be required by the Registered Design Professional (RDP) in responsible charge or by the building official per IBC Section 1704.6.1. The RDP shall submit written statements to the building official prior to the commencement of observations (identifying frequency and extent of observations) and at the conclusion of work included in the permit (describing the site visit(s) performed and identifying any deficiencies that have not been resolved). Submit all statements to inspectionreports@mercerisland.gov

*Structural Observation* for this project is required by the:

Registered Design Professional  Building Official (City use only)

**GEOTECHNICAL INFORMATION**  
 Per Mercer Island City Code, designated geologic hazard areas require a geotechnical report and a statement of risk from a geotechnical professional to be included with the project submittal. Refer to MICC 19.07.160(B)(3) for statement of risk, and City GIS at <https://www.mercerisland.gov/igs> for hazard mapping. Some proposals may require a site restoration bond.

**NO GEOTECHNICAL REPORT REQUIRED**  
 No geotechnical report is required due to either: 1. The absence of geologic hazards on site or 2. Scope of project does not include foundation construction, excavation, or alterations to a hazard (if a report is available or referenced it should be provided)

**GEOTECHNICAL REPORT IS REQUIRED AND INCLUDED WITH SUBMITTAL**  
 A geotechnical report is required and has been provided. All construction must comply with the recommendations of the geotechnical report, and a copy of the report and any other geotechnical information must be kept on site at all times.

Geotechnical Engineer: \_\_\_\_\_ Phone: \_\_\_\_\_ Project or report #: \_\_\_\_\_

**SEASONAL DEVELOPMENT LIMITATION - MICC 19.07.160(F)(2)** limits certain development between Oct 1 and Apr 1

An application for Seasonal Development Limitation Waiver will be submitted and approved prior to any such activity.  
 No grading or excavation will occur between October 1st and April 1st. SDL waiver not applicable.

The City requires an applicant paid peer review when the Building Official determines any of the following are present:

- Advanced excavation or foundation systems, i.e. soil nail walls, tieback shoring systems, etc.
- Foundation systems not supported on competent soils, i.e. over-excavation, soil preloading, etc.
- Projects that require slope stability analysis or those which could pose a significant risk to adjacent properties or structures.
- Where liquefaction presents significant risk (at waterfront or other high water table with seismic mapping)

**GENERAL REQUIREMENTS FOR**  NEW SINGLE FAMILY BUILD  DEMOLITION/REBUILD  ADDITION  REMODEL  REPAIR  DOCK  SITE IMPROVEMENTS  SEISMIC RETRO

Construction of the project shall be from **approved plans only**. No deviation from the approved project plans is allowed without prior approval from the City of Mercer Island. Approved plans must be kept on site and maintained in good condition.

Refer to "Conditions of Permit Approval" provided at permit issuance for required construction rules and regulations, including:

- Site Considerations
- Hours of Work
- Construction Vehicle Parking Restrictions
- Access Road Requirements
- ROW restrictions
- Drainage Requirements
- Sewer Requirements
- Water Service Requirements
- Additional Fire Code Requirements
- Planning Requirements
- Noise Abatement Certification
- Tree Requirements

PRECONSTRUCTION MEETING REQUIRED. Refer to the "Preconstruction Meeting Checklist" notes for additional requirements.  
 Temporary site address with minimum 6" high numbers visible from the street must be installed.  
 Erosion control measures must be as shown on approved project drawings. All erosion control is to be in place and inspected prior to the start of any work.  
 A City of Mercer Island Business License is required for all subcontractors. Call (206) 275-7602 for more information.  
 Additional rockeries, patios, gravel or concrete paths, and other hardscape revisions to the project shall be submitted to the City for review and approval prior to installation.

**LEGAL NONCONFORMANCE/STORMWATER THRESHOLD**  
 Certain thresholds in the Land Use Code (MICC 19) or Stormwater Code (MICC 15.09) can have a significant impact on the requirements to conform with current code. Take special care to conform to the construction documents as-issued to avoid additional improvements.

This project includes modification of legally nonconforming structures - MICC 19.01.050  
 This project retains existing construction to limit calculation of *New Plus Replaced Hard Surface* - MICC 15.09

**TREE REQUIREMENTS**  
 TREE REMOVAL NOT SHOWN ON APPROVED PLAN MAY REQUIRE A SEPARATE TREE PERMIT - REFER TO MICC 19.10

Tree protection as shown on approved drawings shall be installed at tree dripline prior to start of any site work and must remain in place throughout the project. Tree damage due to failure to follow approved plans shall result in fines per MICC 19.19.160.  
 Replacement conifer trees must be a minimum of six feet tall at installation. Deciduous trees must have a minimum caliper of 1-1/2 inches. They must be planted and approved prior to final inspection.  
 For this project, \_\_\_\_\_ trees are authorized to be removed and replaced with \_\_\_\_\_ trees.  
 This project may be within a protected eagle nest area. Contact Federal Fish and Wildlife at (360) 534-9304 or visit their website at [www.fws.gov/pacific/eagle](http://www.fws.gov/pacific/eagle).

**FIRE PROTECTION REQUIREMENTS**  
 Separate Permits are required for ALL fire protection systems. Fire Inspections can be requested at eastsidefire-rescue.org using the QR above, and require 48 hour advanced notice. Do not request fire inspections via MBP or on the general inspection line.

<input type="checkbox"/> Fire Sprinkler	<input type="checkbox"/> Monitored Household
<input type="checkbox"/> NFPA 13D	Fire Alarm per NFPA 72
<input type="checkbox"/> Full Coverage	<input type="checkbox"/> Monitored Sprinkler
<input type="checkbox"/> NFPA 13R	Water Flow Alarm
<input type="checkbox"/> NFPA 13	Other: _____
<input type="checkbox"/> Approved Fire Code Alternatives (FCA):	
<input type="checkbox"/> FCA1	<input type="checkbox"/> FCA3
<input type="checkbox"/> FCA2	<input type="checkbox"/> FCA4

**WATER SERVICE REQUIREMENTS**

New or upsized water supply system required.  
 Water service pre-con meeting and parts inspection are required prior to scheduling the water tap with the City. Schedule these inspections under the water service permit

Applicant Installation

- Minimum Service Line Size (main to meter): \_\_\_\_\_
- Minimum Supply Line Size (meter to house): \_\_\_\_\_
- Minimum Required Meter Size: \_\_\_\_\_

Abandonment of existing service and meter required at main.  
 City Inspector must verify water supply line (water meter to the house) sizing prior to final inspection. Upsizing may be required.

Additional water supply requirements:  
 • Contractor shall provide water supply that meets the required fire sprinkler system fire flow. Fire calculations or fire flow testing outcome may require a larger water service/meter or water supply line.  
 • Pressure reducing valve required if water pressure exceeds 80 psi.  
 • Reduced pressure backflow assembly (RPBA) required for all waterfront lots and for lots with potential connection to non-city water supply. See [mercerisland.gov/backflow](http://mercerisland.gov/backflow)

For additional information about Water Service Inspection process: <https://www.mercerisland.gov/cpd/page/water-service>

**STORMWATER MANAGEMENT**  
 The storm drainage system shown on the approved plans shall be constructed and approved by the City Inspector prior to the construction of the roof, driveway, and other impervious surface that generate runoff from the project.

<input type="checkbox"/> Dispersion / Infiltration system	<input type="checkbox"/> Run-off treatment (MR #8)
<input type="checkbox"/> On-site detention system (MR #5)	<input type="checkbox"/> Connect / Extend public drainage system
<input type="checkbox"/> Direct discharge to lake	<input type="checkbox"/> Full size storm drainage as-built
<input type="checkbox"/> Rain Garden / Bioretention / Permeable Pavement	<input type="checkbox"/> Drainage review not required
<input type="checkbox"/> Flow control system (MR #7)	<input type="checkbox"/> Other: _____

**SIDE SEWER REQUIREMENTS**

Side sewer requires a backflow preventer due to: a connection to the lake line, or elevation of the lowest plumbing fixture is lower than the elevation of the upstream manhole rim, or side sewer is shared with one or more properties

Video tape of existing sewer required (see standard details)

New connection  Connect to existing  Disconnect permit required  Reconnect permit required  
 Other: \_\_\_\_\_

**APPROVED CODE ALTERNATIVES**  
 Code alternatives must be approved by the Building Official prior to permit issuance. All code alternatives must be inspected. Refer to the adjacent Required Construction Inspections checklist.

CA1: \_\_\_\_\_  CA2: \_\_\_\_\_

**PROJECT ALERTS AND NOTES TO INSPECTORS**

**WILDLAND/URBAN INTERFACE**  
 -RESERVED FOR FUTURE USE-

**REQUIRED CONSTRUCTION INSPECTIONS**  
 It is the applicant's responsibility to contact CPD to schedule ALL inspections applicable to the project. Request inspections online at [www.MyBuildingPermit.com](http://www.MyBuildingPermit.com) or by calling the Inspection Hotline at (206) 275-7730. Each MBP inspection type is in [square brackets]. Refer to FIRE PROTECTION REQUIREMENTS for information on scheduling a fire inspection.

**Inspections marked with "\*" are not building permit inspections, and should be requested under the appropriate permit number. Refer to the packet provided at permit issuance or search by address at mybuildingpermit.com for other issued permit numbers.**  
**INSPECTIONS:** (Listed in order of typical sequencing)

Inspector	Date	Approved	Inspection Description	MBP.com Inspection Name	PARTIAL 1	PARTIAL 2	PARTIAL 3
_____	_____	<input type="checkbox"/>	Pre-construction Meeting to Review Conditions of Permit Approval	[PRE-CON MTG GENERAL]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Tree protection	[TREE PROTECTION]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Erosion control	[EROSION CNTRL]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Sewer disconnect and cap	[SIDE SEWER DISCONNECT]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Right-of-way use or work / easement, material delivery, etc. If applicable, separate ROW permit required	[ROW OR UTILITY IMPRO]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Land clearing, grading and demolition	[FINAL DEMO]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Pilings / Shoring / Shotcrete. If applicable, provide survey letter (property line); Geotechnical Engineer / Special Inspector reports of inspections (pile and shoring installation, etc.)	[FOUNDATION WALLS/CON]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Footings, setbacks, UFER ground. If applicable, provide survey letter (building height and setbacks); Special Inspector reports of inspections (soil bearing capacity, compaction, earthwork, pile installation, etc.)	[FOOTINGS, SETBACKS, U]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Foundation walls / concrete columns	[FOUNDATION WALLS/CON]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Roof and footing drains	[CONVEYANCE FACILITY]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Foundation damproofing	[FOUND DAMP PROOFING]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Storm drainage, including (but not limited to)	[CONVEYANCE FACILITY]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	• Connections to storm main in ROW		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	• Area drains		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	• Det systems / Conveyance / Flow control		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	• Storm drain in ROW		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	• Infiltration systems / L.I.D. systems		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	• Pump systems		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	• Catch basins		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Water Service	[3. WATER SERVICE TAP]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Water Supply	[WATER SUPPLY LINE]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Side sewer installation, including (but not limited to)	[SIDE SEWER INSTALLAT]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	• Connections to side sewer main		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	• Back-flow valves		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	• Connections to existing side sewer		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	• Grinder pump systems		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Driveway / Access road	[ROW OR UTILITY IMPRO]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Underslab electrical / mechanical / plumbing	[UNDER-SLAB ELECT/MEC]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Underslab insulation / vapor barrier / reinforcing	[UNDER-SLAB INSULATION]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Underfloor framing	[UNDER-FLOOR FRAMING]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Nailing-Roof sheathing (See SF2 for Required Agency Inspection)	[NAILING-ROOF SHEATHING]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Shear wall construction (See SF2 for Required Agency Inspection)	[NAILING-EXTERIOR WALL]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Rough hydronic installation	[ROUGH HYDRONIC PIPIN]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Rough electric installation	[ROUGH ELECTRIC]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Rough fire alarm (wiring inspection)	[ROUGH-IN LOW VOLTAGE]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Rough plumbing installation (DWW, water)	[ROUGH PLUMBING]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Rough mechanical	[ROUGH MECHANICAL/HVA]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Electrical service	[ELECTRICAL SERVICE]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Gas Piping & Test	[GAS PIPING/TEST]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Rough fire sprinkler / hydrostatic and flow (bucket) test	[ROUGH SPRINKLER RES/STATUS]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Framing and glazing. (See SF2 for Required Agency Inspection)	[FRAMING (& GLAZING)]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Masonry construction (fireplace / walls / veneer / etc.)	[MASONRY]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Insulation installation	[INSULATION]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Stucco (paper and lath)	[STUCCO]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Shower pan (or tub)	[SHOWER PAN (OR TUB)]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Weather exposed balcony and walking surface waterproofing	[ROOF DECK WATERPROOFING]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Code Alternative CA1	[CODE ALT 1]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Code Alternative CA2	[CODE ALT 2]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**FINAL INSPECTIONS**

Inspector	Date	Final Fire Inspection: Tree Restoration [FINAL_TREE]	Final Fire Inspection: Fire protection [FINAL_FIRE_ALL SYSTEMS/ACCESS]	Inspector	Date	[TCO_TREE]	[TCO_FIRE]
_____	_____	<input type="checkbox"/>	• Sprinkler	_____	_____	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	• Access Road	_____	_____	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	• Fire Code Alternatives (see below)	_____	_____	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	<input type="checkbox"/> FCA1	_____	_____	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	<input type="checkbox"/> FCA2	_____	_____	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	<input type="checkbox"/> FCA3	_____	_____	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	<input type="checkbox"/> FCA4	_____	_____	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	<input type="checkbox"/> FCA4	_____	_____	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Final Civil Inspection: Site and utility, landscape, utilities, ROW, and Site [FINAL_CIVIL]	_____	_____	<input type="checkbox"/>	[TCO_CIVIL]
_____	_____	<input type="checkbox"/>	Water supply protection/Backflow devices for:	_____	_____	<input type="checkbox"/>	[TCO_BLDG]
_____	_____	<input type="checkbox"/>	• Waterfront property	_____	_____	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	• Fire / lawn sprinkler	_____	_____	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	• Well water on property	_____	_____	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	• Boiler	_____	_____	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Final Building Inspection: [FINAL_BUILDING] provide closeout (summary) letters from Engineer, Special Inspectors, Geotechnical Engineer, and EIFS inspectors.	_____	_____	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Final MEP Inspections: <input type="checkbox"/> Mech <input type="checkbox"/> Electrical <input type="checkbox"/> Plumbing	_____	_____	<input type="checkbox"/>	<input type="checkbox"/>
_____	_____	<input type="checkbox"/>	Impact Fees Paid (if applicable)	_____	_____	<input type="checkbox"/>	<input type="checkbox"/>

**90 DAY TEMPORARY CERTIFICATE OF OCCUPANCY (TCO)**  
 Applicant option. Additional fees required. All TCO Approvals above must be complete.

Approved \_\_\_\_\_ Start Date \_\_\_\_\_ End Date \_\_\_\_\_

**ADDITIONAL REQUIRED CITY INSPECTIONS**  
 Use the contact information below to arrange these additional inspections.

Required Inspection(s):	Contact:	Contact email:
_____	_____	_____
_____	_____	_____
_____	_____	_____

**IMPACT FEES**  
 If required for the project but deferred beyond permit issuance.

Impact fees apply and are due **prior** to Final Inspection or on \_\_\_\_\_, whichever occurs first.

Date \_\_\_\_\_

**PLAN REVIEW APPROVALS**  
 Not all review disciplines may be required to review the documents.

Building	Planning	Engineering	Tree	Fire
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____

**APPROVED DRAWINGS MUST BE KEPT ON THE BUILDING SITE AT ALL TIMES**  
**REVIEWED FOR CODE COMPLIANCE**

Approved \_\_\_\_\_ Date \_\_\_\_\_


TO BE COMPLETED BY APPLICANT TO BE COMPLETED BY CITY



# FONG ADDITION

## 8801 SE 56TH STREET MERCER ISLAND, WA 98040

### VICINITY MAP



### BUILDING AREA

MAIN FLOOR: 2670 SF (GARAGE: 520 SF)  
UPPER FLOOR: 1080 SF (NEW ADDITION)  
TOTAL:  
2670 + 1080 = 3750 SF

### GROSS FLOOR AREA

ALLOWABLE: 40% OF 11025 = 4410 SF  
MAIN FLOOR: 2670 SF (GARAGE: 520 SF)  
UPPER FLOOR: 1080 SF (NEW ADDITION)  
TOTAL:  
2670 + 1080 = 3750 SF OR 34.0%

### LOT COVERAGE LOT SLOPE

LOT AREA: 11025 SF  
BUILDING FOOTPRINT:  
HOUSE: 2150 SF  
GARAGE: 520 SF  
COVERED PATIO/PORCH: 70 SF  
DRIVEWAY: 290 SF  
ALLOWABLE LOT COVERAGE: 11025 x 0.40 = 4410 SF  
PROPOSED LOT COVERAGE:  
2150 + 520 + 70 + 290 = 3030 SF OR 27.5%

HIGHEST EL: 336.5' - LOWEST EL: 334.5' = 2.0'  
Z / 143.7' (HORIZ. DIST. BTWN. HIGHEST & LOWEST EL) = 0.014  
LOT SLOPE IS 1.4%, SO 40% LOT COVERAGE IS ALLOWED.

### AVE. BLDG. ELEV.

AVERAGE BUILDING ELEVATION			
	Wall Length	Elevation Pt.	Wall Length x Elev. Pt.
A	13.25	335	4441.25
B	15.5	335	5192.5
C	15.5	335	5192.5
D	12.1	335	4053.9
E	5	335	1675
F	4.5	335	1507.5
G	29.5	335	9882.5
H	22.5	335	7537.5
I	13.5	335	4522.5
J	43.75	335	14653.25
K	29.5	335	9882.5
L	25.3	335	8475.9
M	5.1	335	1718.5
N	12.3	335	4120.5
O	5.1	335	1718.5
P	21.75	335	7300.25
	<b>292.65</b>	<b>335</b>	<b>89037.75</b>
	89037.75		335
	292.65		Average Building Elevation

### BUILDING HEIGHT

ALLOWABLE HEIGHT: 30'-0"  
PROPOSED HEIGHT: 24'-5" ABOVE AVE. GRADE  
(SEE ELEVATIONS ON SHEETS A3.0 & A3.1)  
GROUND DISTURBANCE: 0 SF

### SYMBOL LEGEND

GRID LINE	④	REVISION CLOUD	SEE TITLE BLOCK FOR REVISION W/ MOST RECENT CLOUD
DETAIL BUG	1 Ref A3.0	REVISION NUMBER	①
ELEVATION	1 Ref A3.0	NORTH ARROW	PROJECT NORTH TRUE NORTH
WALL SECTION	1 Ref A4.0	WINDOW NUMBER	Ⓐ
DATUM	⊕	DOOR NUMBER	104
		WALL PARTITION TYPE	①

### INDEX OF DRAWINGS

- T1.0 COVER SHEET, SITE PLAN, PROJECT INFORMATION
- T1.1 GENERAL NOTES, ABBREVIATIONS, SYMBOLS
- A2.0 MAIN FLOOR PLAN AND NOTES
- A2.1 UPPER FLOOR PLAN AND NOTES
- A2.2 ROOF PLAN AND SCHEDULES
- A3.0 EXTERIOR ELEVATIONS
- A3.1 EXTERIOR ELEVATIONS
- A4.0 BUILDING SECTION
- A5.0 ARCHITECTURAL DETAILS
- S1.0 STRUCTURAL COVER SHEET
- S1.1 GENERAL STRUCTURAL NOTES
- S2.0 FOUNDATION AND MAIN FLOOR FRAMING PLAN
- S2.1 UPPER FLOOR FRAMING PLAN
- S2.2 ROOF FRAMING PLAN
- S3.0 FOUNDATION & FRAMING DETAILS
- S3.1 WALL FRAMING DETAILS

### SITE PLAN LEGEND

- PROPERTY LINE
- SETBACK LINE
- X- TEMPORARY SILT FENCE
- A INDICATES WALL SEGMENT FOR ABC CALC
- W EX. WATER LINE
- PROPOSED IMPERVIOUS SURFACE AREA
- PROPOSED PERVIOUS SURFACE AREA
- IMPERVIOUS SURFACE AREA TO BE REMOVED
- ADDED / REPLACED IMPERVIOUS SURFACE AREA

### HARDSCAPE

EXISTING HARDSCAPE AREA:	0 SF
DECKS	0 SF
WALKS, PATIOS	890 SF
TOTAL EXISTING AREA	890 SF
EXISTING HARDSCAPE TO REMAIN:	0 SF
DECKS	0 SF
WALKS, PATIOS	890 SF
TOTAL REMAINING EXISTING AREA	890 SF
EXISTING HARDSCAPE TO BE REMOVED:	0 SF
DECKS	0 SF
WALKS, PATIOS	0 SF
TOTAL REMOVED EXISTING AREA	0 SF
NEW / REPLACE HARDSCAPE AREA:	0 SF
DECKS	0 SF
WALKS, PATIOS	0 SF
TOTAL NEW / REPLACE AREA	0 SF
TOTAL PROPOSED HARDSCAPE AREA	890 SF

### IMPERVIOUS SURFACE

EXISTING IMPERVIOUS SURFACE AREA:	3700 SF
HOUSE & ROOF	3700 SF
DECKS	0 SF
DRIVEWAY, WALKS, PATIOS	890 SF
TOTAL EXISTING AREA	4590 SF
EXISTING IMPERVIOUS SURFACE TO REMAIN:	3700 SF
HOUSE & ROOF	3700 SF
DECKS	0 SF
DRIVEWAY, WALKS, PATIOS	890 SF
TOTAL REMAINING EXISTING AREA	4590 SF
EXISTING IMPERVIOUS SURFACE TO BE REMOVED:	0 SF
HOUSE & ROOF	0 SF
DECKS	0 SF
DRIVEWAY, WALKS, PATIOS	0 SF
TOTAL REMOVED EXISTING AREA	0 SF
NEW / REPLACE IMPERVIOUS SURFACE AREA:	0 SF
HOUSE & ROOF	0 SF
DECKS	0 SF
DRIVEWAY, WALKS, PATIOS	0 SF
TOTAL NEW / REPLACE AREA	0 SF
TOTAL PROPOSED IMPERVIOUS SURFACE AREA	4590 SF

### DEVELOPMENT STANDARDS

YARDS:  
FRONT - 20 FT.  
REAR - 25 FT.  
SIDE - 10 FT.  
GROSS FLOOR AREA: 40% LOT AREA  
MAX. BLDG. HEIGHT: 30 FT. ABOVE A.B.E. TO HIGHEST POINT OF ROOF  
30 FT. FACADE HT. FROM DOWNHILL SIDE OF SLOPING LOT  
MAX. LOT COVERAGE: 40% LOT AREA FOR LOT SLOPE LESS THAN 15%  
LANDSCAPE AREA: 60% LOT AREA

### TREE LEGEND

- TREE TO REMAIN
- ⊗ TREE TO BE REMOVED
- ②④⑤ TREE NUMBER PER ARBORIST REPORT
- TREE PROTECTION FENCING PER SHEET C1.0

Truss package shall be submitted for review and approval to the city prior to manufacturer and delivery on site.



### PROJECT INFORMATION

PROJECT ADDRESS  
8801 SE 56TH STREET  
MERCER ISLAND, WA 98040

JURISDICTION  
MERCER ISLAND

PARCEL NUMBER  
667290-0240

LEGAL DESCRIPTION  
PARKWOOD ESTATES ADD  
PLAT BLOCK 2  
PLAT LOT: 8

SITE AREA  
11,025 SF

ZONING  
R-9.6

### PROJECT DESCRIPTION

NEW 1080 SF UPPER FLOOR ADDITION TO AN EXISTING 2150 SF ONE-STORY SINGLE-FAMILY RESIDENCE WITH ATTACHED 520 SF TWO-CAR GARAGE.

- TRADES UNDER SEPARATE PERMIT:
- PLUMBING
  - MECHANICAL
  - ELECTRICAL
  - FIRE SPRINKLERS

### BUILDING CODE INFO

CODE EDITION: 2021 IRC, 2021 WSEC RESIDENTIAL

CONSTRUCTION TYPE: V8 NON-RATED

OCCUPANCY GROUP: R-3 (HOUSE & ADU) / U (GARAGE)

FIRE SPRINKLERS: NFPA 72 SYSTEM  
A NFPA 72 - CHAPTER 29 MONITORED FIRE ALARM SYSTEM IN COMPLIANCE WITH NFPA 72 AND COMI STANDARDS SHALL BE INSTALLED THROUGHOUT THE RESIDENCE. A SEPARATE FIRE PERMIT IS REQUIRED.

WHOLE HOUSE VENTILATION:  
EXHAUST FANS AND WHOLE HOUSE MECHANICAL VENTILATION FANS SHALL BE LISTED AND LABELED AS PROVIDING MINIMUM REQUIRED AIRFLOW IN ACCORDANCE WITH ANSI/AMCA 210-ANSI/ASHRAE 61.

FOR 3001-4500 SF, 4-5 BEDROOMS, PROVIDE CONTINUOUS AIRFLOW IN 90 CFM.

### PROJECT DIRECTORY

OWNERS: RUBY AND CEDRIC FONG  
RUBYCEDRIC@GMAIL.COM  
P 206.618.1773

ARCHITECT: HECKMAN ARCHITECTS  
501 ROY ST., SUITE 232C  
SEATTLE, WA 98109  
P 206.478.6850  
CONTACT: AARON HECKMAN

STRUCTURAL: JP JONES ENGINEERING  
711 SAINT HELENS AVE., SUITE 208  
TACOMA, WA  
P 253.448.7331  
CONTACT: JORDAN JONES


GENERAL CONTRACTOR: SKYLINE CONTRACTING SERVICES  
620 144TH ST SW  
LYNNWOOD, WA 98087  
P 206.707.6667  
CONTACT: ELIAS HAYDARI

### 2021 WSEC TABLE 406.2

SMALL DWELLING UNIT:	5.0 CREDITS REQUIRED (ADDITIONS TO EXISTING BUILDINGS 500-1500 SF OF HEATED FLOOR AREA)
1.2 - VERTICAL FENESTRATION U = 0.25; FLOOR R-38; SLAB ON GRADE R-10 ENTIRE SLAB	1.0 CREDITS
2.1 - AIR LEAKAGE AND EFFICIENT VENTILATION 2.0 AIR CHANGES PER HOUR MAX. AT 50 PASCALS	1.0 CREDITS
3.1 - ENERGY STAR RATED GAS FURNACE WITH MIN. AFUE OF 95%	1.0 CREDITS
5.6 - ELECTRIC HEAT PUMP WATER HEATER MEETING STANDARDS FOR TIER III OF NEEAS SPEC	2.0 CREDITS
TOTAL	5.0 CREDITS



**HECKMAN**  
architects  
501 ROY ST, STE C232  
SEATTLE, WA 98109  
aheckman@gmail.com  
(206) 478-6850  
HECKMANarchitects.com



All Rights Reserved © 2024

**FONG ADDITION**  
8801 SE 56TH STREET  
MERCER ISLAND, WA 98040

**SITE & ROOF PLAN**  
**PROJECT INFORMATION**  
**ZONING CALCULATIONS**

REVISIONS:	10/29/24 PERMIT RESPONSE
PERMIT INTAKE DATE:	07/17/2024
PLOT DATE:	11/4/2024
SHEET NUMBER:	T1.0

## ABBREVIATIONS

@	AT CENTERLINE	GA. GAGE	SPEC SPECIFICATION
⊕	PROPERTY LINE	GALV. GALVANIZED	SQ. SQUARE
P	PENNY	GRAB BAR	S.S. SERVICE SINK
⊥	PERPENDICULAR	GEN. GENERAL	S.S.D. SEE STRUCTURAL DRAWINGS
#	POUND OR NUMBER	GL. GLASS, GLAZING	S.TL. STAINLESS STEEL
∅	DIAMETER	GND. GROUND	S.D. STANDARD
⊠	SQUARE FEET	GR. GRADE, GRADING	STL. STEEL
A.B.	ANCHOR BOLT	GWB. GYPSUM WALL BOARD	STOR. STORAGE
A/C	AIR CONDITIONING	GYP. GYPSUM	STRUCTL. STRUCTURAL
ACC.	ACCESSIBLE	GLSS. GLASS FIBER REINF. CONC.	SUSP. SUSPENDED
ACOUS.	ACOUSTICAL	H.B. HOSE BIBB	T. TREAD
ACT	ACOUSTIC TILE	H.C. TOWEL CORE	T.B. TOWEL BAR
A.D.	REA DRAIN	HD. HEAD	TEL. TELEPHONE
ADD.	ADDENDUM	HDB. HARDBOARD	TEMP. TEMPRED
ADJ.	ADJACENT	HDR. HEADER	TERR. TERRAZZO
ADJUS.	ADJUSTABLE	HOWD. HARDWOOD	TEX. TEXTURE(D)
AFF.	ABOVE FINISH FLOOR	HOWR. HARDWARE	T&G. TONGUE AND GROOVE
AGGR.	AGGREGATE	HM. HOLLOW METAL	THK. THICKNESS
ALT.	ALTERNATE	HZ. HORIZONTAL	THRESH. THRESHOLD
ALUM.	ALUMINUM	HT. HEIGHT	T.J. TOOLED JOINT
ANOD.	ANODIZED	HTG. HEATING	T.KBD. TACKBOARD
APPROX.	APPROXIMATE	HVAC. HEATING/VENTILATING/	T.V. TELEVISION
ARCH.	ARCHITECT	HR. HOUR	TYP. TYPICAL
ARCH'L.	ARCHITECTURAL	HW. HOT WATER HEATER	T.O.C. TOP OF CONCRETE
ASPH.	ASPHALT	I.D. INSIDE DIAMETER	T.O.C. TOP OF STL.
AV.	AUDIOVISUAL	INCL. INCLUDING	UNFIN. UNFINISHED
BRD.	B BOARD	INSUL. INSULATION	UNON. UNLESS OTHERWISE NOTED
BTWN.	BETWEEN	INT. INTERIOR	
BLDG.	BUILDING	INV. INVERT	
BLK. B	LOCK	VAR. VARNISH	
BLKG.	BLOCKING	VNT. VINYL COMPOSITION TILE	
BM.	BEAM	VIF. VERIFY IN FIELD	
B.M.	BENCH MARK	VNR. VENEER	
B.T.	BATH	VRF. VERIFY	
BRG.	BEARING	VERT. VERTICAL	
BRZ.	BRONZE	VST. VESTIBULE	
BZMT.	BASEMENT	V.G. VISION GRILLE	
B.U.R.	BUILT UP ROOF	V.V.C. VINYL WALL COVERING	
CAB.	CABINET	W. WEST, WIDE	
C.B.	CATCH BASIN	WITH	
CMENT.	CEMENT	WAB. WATER/AIR BARRIER	
CER.	CERAMIC	W.C. WATER CLOSET	
C.G.	CORNER GUARD	WD. WOOD	
CHAMF.	CHAMFER	WH. WATER HEATER	
C.C.	CUT IRON	WO. WITHOUT	
C.I.P.	CAST-IN-PLACE(Concrete)	WP(G) WATERPROOFING	
CIRC.	CIRCLE	WRB. WATER RESISTANT BARRIER	
C.J.C.	CONTROL JOINT	WSCOT. WAINSCOT	
CLG. CLMG.	CEILING	WT. WEIGHT	
CLR.	CLEARANCE	W.W.F. WELDED WIRE FABRIC	
CMU.	CONCRETE MASONRY UNIT		
CNTR.	COUNTER		
C.O.C.	LEAN OUT		
COL.	COLUMN		
CONC.	CONCRETE		
CONN.	CONNECTION		
CONST.	CONSTRUCTION		
CONT.	CONTINUOUS		
CONTR.	CONTRACTOR		
CORR.	CORRIDOR		
CPT.	CARPET		
CRS.	COURSING		
CSMT.	CASEMENT		
C.T.	CERAMIC TILE		
CTR.	CENTER		
CSK.	COUNTER SINK		
CU FT.	CUBIC FOOT		
CU YD.	CUBIC YARD		
D/B.	DESIGN BUILD		
DEMO.	DEMOLITION		
DBL.	DOUBLE		
D.L.	DEAD LOAD		
DETL.	DETAIL		
D.F.	DRINKING FOUNTAIN		
D.H.	DOUBLE HUNG		
DIAG.	DIAGONAL		
DIAM.	DIAMETER		
DIM.	DIMENSION		
DIV.	DIVISION		
DN.	DOWN		
DP.	DAMP/PROOFING		
DPR.	DISPENSER		
DR.	DOOR		
DS.	DOWNSPOUT		
D.T.	DRAIN TILE		
DWG.	DRAWING		
DWR.	DRAWER		
(E)	EXISTING		
E.	EAST		
EA.	EACH		
E.I.F.S.	EXTERIOR INSULATED FINISH SYSTEM		
E.J.T.	EXPANSION JOINT		
ELEV.	ELEVATION		
ELEC(L)	ELECTRIC(AL)		
ELEV.	ELEVATOR		
ENCL.	ENCLOSURE		
ENG.	ENGINEER		
EQ.	EQUAL		
EQUIP.	EQUIPMENT		
ESC.	ESCALATOR		
EST.	ESTIMATE		
EXCAV.	EXCAVATE		
EXH.	EXHAUST		
EXIST.	EXISTING		
EXP.	EXPANSION		
EXT.	EXTERIOR		
FBIOC.	FURNISHED BY OWNER		
FBIOO.	INSTALLED BY CONTRACTOR		
FCB.	FIBER CEMENT BOARD		
F.D.	FLOOR DRAIN		
FDN.	FOUNDATION		
F.E.	FIRE EXTINGUISHER		
F.E.C.	FIRE EXTINGUISHER CABINET		
F.F.	FACTORY FINISH		
FIN.	FINISHED		
FLR(G)	FLOORING		
FLSHG.	FLASHING		
FLUOR.	FLUORESCENT		
F.O.S.	FACE OF STUDS		
F.O.C.	FACE OF CONCRETE		
F.O.F.	FACE OF FINISH		
F.O.B.	FACE OF BRICK		
F.O.M.	FACE OF MASONRY		
FP.	FIREPROOF		
FT.	FOOT, FEET		
FTG.	FOOTING		
FURR.	FURRED		
F.V.T.	FIXED SECURITY TELEVISION		
FURR.	FURRED, FURRING		
FUT.	FUTURE		
F.R.G.	FIBERGLASS REINF. GYPSUM		
FV.	FIELD VERIFY		
F.W.C.	FABRIC WALLCOVERING		

## ELECTRICAL NOTES

- FURNISH AND INSTALL ALL FIXTURES, ASSOCIATED TRIM AND FIXTURE LAMPS AS REQUIRED.
- ARCHITECTURAL DRAWINGS DETERMINE LOCATION AND TYPE (ARCHITECT TO VERIFY W/ ENGINEER) OF ALL OUTLETS AND TAKE PRECEDENCE OVER ALL OTHERS, UNON. ELECTRICAL ENGINEER'S POWER PLAN SHALL GOVERN THE WIRING LAYOUT, PANEL LOCATIONS, AND INSTALLATION IN COMPLIANCE WITH ALL LAWS APPLICABLE AND ENFORCED BY GOVERNING AUTHORITIES.
- OUTLETS SHOWN BACK TO BACK ON PARTITION WALLS SHALL BE OFFSET 1'-0" MAXIMUM, OR MOUNTED AT DIFFERENT HEIGHTS IF INDICATED.
- FURNITURE, IF SHOWN, IS FOR REFERENCE ONLY AND IS NOT IN CONTRACT, UNON.
- COORDINATE ALL WORK RELATED TO EQUIPMENT WITH MANUFACTURERS RECOMMENDATIONS, SPECIFICATIONS AND INSTRUCTIONS.
- ALL FLOOR SLAB PENETRATIONS FOR CONDUIT OR PLUMBING LINES SHALL BE FULLY PACKED & SEALED IN ACCORDANCE WITH THE APPLICABLE BUILDING AND FIRE CODES.
- UPON COMPLETION OF OUTLET LAYOUT, NOTIFY THE ARCHITECT. ARCHITECT SHALL SITE VERIFY ALL OUTLET LOCATIONS PRIOR TO COMMENCEMENT OF CORDING OR LAUETL INSTALLATION.
- FURNISH AND INSTALL ONLY UNDERWRITERS LABORATORIES, INC. (UL) LABELED DEVICES THROUGHOUT.
- INSTALL WALL MOUNTED OUTLETS 18 INCHES ABOVE FINISHED FLOOR, U.O.N. HEIGHTS SHALL BE DETERMINED FROM FINISHED FLOOR TO THE CENTERLINE OF COVERPLATE, INSTALLED VERTICALLY, GROUNDING POLE AT BOTTOM, UNON.
- MAINTAIN A 4-INCH HORIZONTAL CLEARANCE IN ALL DIRECTIONS, MIN. FROM EDGE OF COVERPLATE, FOR WALL MOUNTED OUTLETS, OR FROM EDGE OF MOUNT FOR FLOOR MOUNTED OUTLETS, WHEN ADJACENT TO A WALL, COLUMN, OR SIMILAR ELEMENTS, UNON.
- INDICATED DIMENSIONS ARE TO THE CENTER OF THE COVERPLATE OR MONUMENT. CLUSTERS OF OUTLETS ARE DIMENSIONED TO THE CENTER OF THE CLUSTER, UNON. GANG COVERPLATES SHALL BE ONE-PIECE TYPE, UNON.
- ELECTRICAL SWITCH AND OUTLET COVER PLATES, SURFACE HARDWARE, ETC. SHALL BE INSTALLED AFTER PAINTING AND/OR APPLICATION OF WALLCOVERINGS & CARPET SPECIFIED.
- "H" INDICATES THAT AN OUTLET SHALL BE MOUNTED HORIZONTALLY.
- ALL SWITCHES AND DIMMERS SHALL BE LOCATED 46" ABOVE FINISHED FLOOR TO CENTER OF SWITCH UNON. MULTIPLE SWITCHES AT ONE LOCATION SHALL BE GANGED TOGETHER AND FINISHED WITH ONE COVER PLATE UN.
- RECEPTACLE SPACING SHALL BE A MAXIMUM OF 12'-0"

## SUBMITTAL NOTES

- SUBMIT DOCUMENTS ELECTRONICALLY IN PDF FORMAT WHEN POSSIBLE.
- SUBMIT NO FEWER THAN TWO EACH OF PRODUCT SAMPLES, ONE OF WHICH WILL BE RETAINED BY ARCHITECT.
- FOR EACH SUBMITTAL REVIEW, ALLOW 10 DAYS FOR EACH OFFICE WHO MUST REVIEW THE SUBMITTAL. NOTE VARIATIONS FROM CONSTRUCTION DOCUMENTS OR PRODUCTS SPECIFIED.
- GC TO PROVIDE FULL COORDINATED SHOP DRAWINGS FOR REVIEW & APPROVAL PRIOR TO BEGINNING FABRICATION FOR THE FOLLOWING ITEMS: STRUCTURAL & ARCHITECTURAL METAL FABRICATIONS, CASEWORK, SPRINKLER LAYOUT, DOORS, GLAZING (WHITEBOARDS, PANELS, ETC), RELIGHTS & FRAMES. PROVIDE LAYOUT/ SEAMING DIAGRAMS FOR TILE, CARPET, UPHOLSTERY, SPECIALTY WALL PANEL (FABRIC WRAPPED PANELS, TACKBOARD, ETC)
- GC TO PROVIDE CUT SHEET/ PRODUCT DATA SUBMITTALS FOR REVIEW & APPROVAL PRIOR TO ORDERING FOR THE FOLLOWING ITEMS: DOOR & CASEWORK HARDWARE, LIGHT FIXTURES, PLUMBING FIXTURES, APPLIANCES, TOILET ACCESSORIES, MECHANICAL (GRILLES, ETC) & FIRE ALARM. PROVIDE CASEWORK PANEL MOCKUPS (12" SQ. MIN.) ILLUSTRATING SUBSTRATE, FINISH & EDGE BAND.
- GC TO PROVIDE SELECTION AND/OR VERIFICATION SAMPLES FOR ALL MATERIALS IN THE FINISH SCHEDULE FOR REVIEW & APPROVAL PRIOR TO ORDER. PROVIDE GLASS SAMPLES WHERE NOT IDENTIFIED IN FINISH SCHEDULE.

## DIMENSION NOTES

- DO NOT SCALE DRAWINGS; WRITTEN DIMENSIONS GOVERN. ALL PARTITION LOCATIONS SHALL BE AS SHOWN ON PARTITION PLAN. IN CASE OF CONFLICT NOTIFY ARCHITECT. PARTITION PLAN BY ARCHITECT TAKES PRECEDENCE OVER ALL OTHER PLANS.
- ALL DIMENSIONS ARE TO FACE OF FRAMING FOR NEW CONSTRUCTION AND FINISHED FACE OF EXISTING CONSTRUCTION, UNLESS OTHERWISE NOTED. CONTACT ARCHITECT FOR CLARIFICATIONS IF REQUIRED.
- DIMENSIONS NOTED "CLEAR" OR "CLR" MUST BE ACCURATELY MAINTAINED, AND SHALL NOT VARY MORE THAN ± 1/8" WITHOUT WRITTEN INSTRUCTION FROM ARCHITECT.
- DIMENSIONS MARKED ± MEAN A TOLERANCE NOT GREATER NOR SMALLER THAN 2 INCHES FROM INDICATED DIMENSION, UNON.
- NOTIFY ARCHITECT IN WRITING OF ANY DISCREPANCIES OR CONFLICTS IN THE LOCATION(S) OF NEW CONSTRUCTION. UPON COMPLETION OF PARTITION LAYOUT, NOTIFY ARCHITECT. VERIFICATION OF THE LAYOUT TO BE PROVIDED BY THE ARCHITECT PRIOR TO PARTITION INSTALLATION.
- REFER TO REFLECTED CEILING PLANS FOR SOFFITS, CEILING HEIGHTS AND PLUMBING BARRIER LOCATIONS.
- DIMENSIONS LOCATING DOORS ARE TO THE INSIDE EDGE OF JAMB, UNON.
- "ALIGN" MEANS TO ACCURATELY LOCATE FINISHED FACES IN THE SAME PLANE.

## FIRE PROTECTION NOTES

- A HEAT DETECTOR OR ALARM RATED FOR AMBIENT OUTDOOR TEMPERATURES AND HUMIDITY SHALL BE INSTALLED IN NEW GARAGES THAT ARE ATTACHED TO OR LOCATED UNDER NEW AND EXISTING DWELLINGS. HEAT DETECTORS AND HEAT ALARMS SHALL BE INSTALLED IN A CENTRAL LOCATION AND IN ACCORDANCE WITH THE MANUFACTURERS INSTRUCTIONS. HEAT DETECTORS SHALL BE CONNECTED TO AN ALARM OR A SMOKE ALARM WITHIN THE DWELLING.

## DEMOLITION NOTES

- UNON, ALL EXTERIOR WINDOWS AND SKYLIGHTS TO BE REPLACED PER GLAZING SCHEDULE.
- ALL REMOVED EXTERIOR STONE TO BE SALVAGED FOR POSSIBLE REUSE.
- ASBESTOS & HAZARDOUS MATERIALS: FEDERAL, STATE & LOCAL REGULATIONS REQUIRE THAT ALL ASBESTOS & OTHER HAZARDOUS MATERIALS IN A BUILDING BE REMOVED PRIOR TO STARTING THE DEMOLITION WORK. CONTRACTOR TO OBTAIN REQUIRED CERTIFICATION THAT THERE ARE NO HAZARDOUS MATERIALS PRESENT IN THE STRUCTURE.
- UNON, ALL DEBRIS RESULTING FROM DEMOLITION WORK SHALL BECOME THE PROPERTY OF THE CONTRACTOR & SHALL BE REMOVED & DISPOSED OF IN A LEGAL MANNER OFF OF THE PROJECT PROPERTY.
- SEE MEP (UNDER SEPARATE PERMIT) FIRE PROTECTION (UNDER SEPARATE PERMIT), ELECTRICAL (UNDER SEPARATE PERMIT) & COMMUNICATION (UNDER SEPARATE PERMIT) DOCUMENTS FOR DEMOLITION RELATED TO THOSE TRADES.
- THE CONTRACTOR SHALL PROTECT THE EXISTING BUILDING & IMPROVEMENTS WITHIN THE AREAS OF OPERATION & TAKE CARE TO PROTECT THE NEIGHBORING SPACES WHERE EXISTS. THE CONTRACTOR SHALL ASSUME ALL FINANCIAL RESPONSIBILITY FOR THE IMMEDIATE RESTORATION, REPAIR, OR REPLACEMENT OF DAMAGED ITEMS OR AREAS TO RESTORE THEM TO MATCH EXISTING CONDITIONS.
- THE CONTRACTOR SHALL TAKE PRECAUTIONS TO ADEQUATELY SECURE THE PREMISES AND/OR STORED MATERIALS FROM TRESPASSING, THEFT & VANDALISM.
- DEMO ALL FLOORING FINISHES IN AREAS OF WORK UNON. PATCH & PREPARE EXISTING FLOORS IN AREAS TO RECEIVE NEW FLOORING TO PROVIDE FOR CONTINUOUS 'LEVEL' SURFACE FOR NEW FLOORING.
- DO NOT REMOVE ANY BEARING WALLS, COLUMNS OR OTHER STRUCTURAL MEMBERS NOT DESIGNATED IN STRUCTURAL DOCUMENTS. NOTIFY ARCHITECT IMMEDIATELY IF AREAS OF DEMO UNCOVER ANY EXISTING STRUCTURAL COMPONENTS NOT PREVIOUSLY IDENTIFIED.
- REMOVE ALL WALLCOVERING INCLUDING GWB ON WALLS TO REMAIN.
- PRIOR TO REMOVAL OF ANY STRUCTURAL COMPONENTS, THE CONTRACTOR SHALL PROVIDE SHORING AS REQUIRED TO TEMPORARILY SUPPORT ALL LOADS UNTIL NEW FRAMING IS INSTALLED AS DOCUMENTED AND SPECIFIED. IF THE CONTRACTOR FINDS THE EXISTING CONDITIONS TO BE OTHER THAN DOCUMENTED OR IN CONFLICT WITH THE DRAWINGS, NOTIFY THE ARCHITECT IMMEDIATELY FOR RESOLUTION. PROCEEDING WITHOUT NOTIFICATION INDICATES FULL ACCEPTANCE OF CONDITIONS AND RESPONSIBILITY IF WORK IS NOT IN CONFORMANCE WITH CONTRACT DOCUMENTS.

## FINISH NOTES

- PROVIDE PAINT APPLICATION APPROPRIATE TO THE SUBSTRATE TO WHICH IT IS TO BE APPLIED.
- ALL EXPOSED GWB SURFACES ARE TO RECEIVE NEW PAINT FINISH U.O.N. PREP ALL SURFACES AS REQUIRED FOR NEW PAINT FINISH. PROVIDE ONE PRIME COAT PLUS TWO FINISH COATS
- CHANGES IN FLOOR MATERIALS THAT OCCUR AT FRAMED DOOR OPENINGS SHALL OCCUR AT THE CENTERLINE OF THE DOOR IN THE CLOSED POSITION.
- CARPET INSTALLATION TO MEET THE GUIDELINES OF THE CARPET AND RUG INSTITUTE-CRI CARPET INSTALLATION STANDARD-CURRENT EDITION.

## ENERGY CODE NOTES:

- ALL NEW CONSTRUCTION TO COMPLY WITH ALTERATION REQUIREMENTS IN WSEC 2021 RESIDENTIAL SECTIONS.
- SEE FLOOR PLAN NOTES FOR MINIMUM R-VALUES AND MAXIMUM U-FACTORS.
- SEE DOOR AND WINDOW SCHEDULES FOR GLAZING SPECS.
- SEE T1.0 FOR WHOLE HOUSE VENTILATION REQUIREMENTS.
- WINDOWS, SKYLIGHTS, AND SLIDING GLASS DOORS SHALL HAVE AN AIR INFILTRATION RATE OF NO MORE THAN 0.3 CFM PER SQUARE FOOT, AND SWINGING DOORS NO MORE THAN 0.5 CFM PER SQUARE FOOT, PER 2021 WSEC SECTION R402.4.3
- AIR LEAKAGE RATE TO BE 4.0 AIR CHANGES PER HOUR (ACH) MAXIMUM PER R402.4.1.3.1.
- WATER HEATERS MUST BE INSTALLED IN CONDITIONED SPACE, EXCEPT FOR HIGHLY EFFICIENCY WATER HEATERS PER R403.5.5.
- MECHANICAL VENTILATION TO BE TESTED AND VERIFIED BY THE CONTRACTOR TO MEET THE MINIMUM FLOW RATE REQUIREMENTS PER R403.6.2.
- ALL NEW INTERIOR LIGHTING MUST BE CONTROLLED BY DIMMERS, OCCUPANT SENSOR CONTROLS, OR BUILT-IN FIXTURE CONTROLS PER R404.2.
- ALL NEW EXTERIOR LIGHTING OVER 30 WATTS MUST BE PROVIDED WITH AUTOMATIC CONTROLS TO TURN OFF DURING DAYLIGHT HOURS PER R404.3.
- WHEN ADDITIONS OVER 150 SF ADJOIN EXISTING ATTIC SPACES, THE EXISTING ATTIC SPACE NEEDS TO BE INSULATED TO CURRENT R402 REQUIREMENTS AND INSULATION VALUES PER R502.3.1.1.
- LIGHTING SHALL COMPLY WITH SECTION R404.1 FOR 10% REPLACEMENT PER R503.1.4.
- FOR NEW CONSTRUCTION PROJECTS WHICH CREATE DWELLING UNITS AND INCLUDE AN ATTACHED GARAGE OR CARPORT, PROVIDE ONE 40 AMP DEDICATED 208/240 VOLT BRANCH CIRCUIT FOR EACH DWELLING UNIT INTENDED FOR FUTURE ELECTRIC VEHICLE CHARGING.
- 2021 WASHINGTON STATE ENERGY CODE MINIMUM RESIDENTIAL REQUIREMENTS OF THE PRESCRIPTIVE PATH FOR ALL CLIMATE ZONES PER TABLE R402.1.3 ARE AS FOLLOWS:
  - FENESTRATION U-FACTOR = 0.30
  - SKYLIGHT U-FACTOR = 0.50
  - CEILING WITH ATTIC R-VALUE = 60
  - VAULTED CEILING R-VALUE = 38
  - WOOD FRAME WALL R-VALUE = 20 + 5 OR 13 + 10
  - FLOOR R-VALUE = 30
  - G. BELOW GRADE R-VALUE = 10 / 15 / 21 INT + 5 TB
  - SLAB R-VALUE & DEPTH = 10, 4 FT.
- THESE ARE TYPICAL MINIMUM VALUES PER 2021 WSEC UNLESS OTHERWISE NOTED IN PLAN SET.
- CONTRACTOR SHALL SPECIFY MAXIMUM TESTED BUILDING AIR LEAKAGE AND SHOW THE QUALIFYING VENTILATION SYSTEM AND ITS CONTROL SEQUENCE OR OPERATION.

## GENERAL NOTES

- DO NOT SCALE DRAWINGS.
- IT IS THE INTENT OF THE CONTRACT DOCUMENTS THAT ALL WORK COMPLY WITH THE WASHINGTON STATE BUILDING CODE, THE WASHINGTON STATE ENERGY CODE, AND OTHER APPLICABLE CODES, RULES AND REGULATIONS OF JURISDICTION HAVING AUTHORITY.
- PRIOR TO COMMENCEMENT OF ANY PORTION OF THE WORK, THE CONTRACTOR SHALL NOTIFY THE ARCHITECT OF ANY DISCREPANCIES NOTED AMONG OR BETWEEN THE CONTRACT DOCUMENTS, OWNER-PROVIDED INFORMATION, SITE CONDITIONS, MANUFACTURER RECOMMENDATIONS, CODE REGULATIONS, OR RULES OF JURISDICTIONS HAVING AUTHORITY.
- PRIOR TO COMMENCEMENT OF ANY PORTION OF THE WORK, THE CONTRACTOR SHALL BECOME FAMILIAR WITH THE CONTRACT DOCUMENTS, OWNER- PROVIDED INFORMATION AND SITE CONDITIONS, INCLUDING TAKING FIELD MEASUREMENTS AS NECESSARY.
- THE CONTRACTOR SHALL PAY FOR AND SECURE ALL GOVERNMENTAL PERMITS, FEES, LICENSES, AND INSPECTIONS NECESSARY FOR PROPER EXECUTION AND COMPLETION OF THE WORK, WITH THE EXCEPTION OF THE GENERAL BUILDING PERMIT AND SPECIAL INSPECTIONS REQUIRING A PROFESSIONAL INSPECTION AND TESTING SERVICE.
- DESIGN-BUILD SERVICES SUCH AS ELECTRICAL, PLUMBING AND MECHANICAL SHALL BE CONDUCTED UNDER SEPARATE PERMITS, FILED AND SECURED BY THE GENERAL CONTRACTOR OR DESIGN-BUILD SUB-CONTRACTOR.
- DRAWINGS INDICATE GENERAL AND TYPICAL DETAILS OF CONSTRUCTION. WHERE CONDITIONS ARE NOT SPECIFICALLY INDICATED, BUT ARE OF SIMILAR CHARACTER TO DETAILS SHOWN, SIMILAR DETAILS OF CONSTRUCTION SHALL BE USED, SUBJECT TO REVIEW BY THE ARCHITECT AND STRUCTURAL ENGINEER OF RECORD.
- THE CONTRACTOR SHALL ASSUME THAT THE SAME FINISH MATERIAL SHALL BE USED FOR ALL SURROUNDING, ABUTTING, AND ADJOINING SURFACES FOR AREAS AND ITEMS NOTED ON THE DRAWINGS, UNLESS OTHERWISE NOTED. AT NO TIME SHALL THE CONTRACTOR CONSIDER, BID, OR INSTALL A DIFFERENT MATERIAL OR TYPE THAN THAT WHICH IS INDICATED ON THE DRAWINGS OR SPECIFICATIONS. QUESTIONS RELATING TO THE SPECIFIC MATERIALS TO BE USED SHALL BE DIRECTED TO THE ARCHITECT PRIOR TO THE BIDDING AND/OR CONSTRUCTION OF WORK IN QUESTION.
- SITE DRAINAGE SHALL CONFORM TO ALL LOCAL CODES, REGULATIONS, AND ORDINANCES. ALL ROOF DRAINS, FOUNDATIONS DRAINS, AND SITE DRAINAGE SYSTEM SHALL BE TIGHT-LINED UNDERGROUND TO THE PUBLIC STORM WATER SYSTEM, AN APPROVED STORM WATER RETENTION SYSTEM, OR TO OTHER LOCATION(S) AS MAY BE INDICATED ON THE DRAWINGS. DO NOT CONNECT THE ROOF DRAINS AND SITE DRAINAGE SYSTEM TO THE FOUNDATION WALL OR RETAINING WALL PERIMETER FOOTING DRAINS. ALL SITE HARDSCAPE SURFACES SHALL HAVE A MINIMUM SLOPE OF 1/4" PER FOOT TO DRAINAGE SYSTEMS, UNLESS OTHERWISE NOTED ON THE PLANS.
- PROVIDE A MIN. 4" DIA ROUND RIGID PERFORATED PERIMETER FOOTING DRAIN IN GRAVEL FILL WITH UNWOVEN FILTER FABRIC WRAP AT THE EXTERIOR FACE OF ALL FOUNDATION WALL FOOTINGS PER IRC SECTION R405.1. LOCATE THE BOTTOM OF THE DRAIN PIPE AT THE LOWEST POINT OF THE WALL FOOTING. TIGHT LINE ALL OF THE PERIMETER DRAINS TO AN APPROVED DISCHARGE, WHEN STORM SEWERS ARE NOT AVAILABLE. DO NOT CONNECT THE ROOF DRAINS AND SITE DRAINAGE SYSTEM TO THE FOUNDATION WALL OR RETAINING WALL PERIMETER FOOTING DRAINS.
- PROVIDE A 6" LAYER OF PEA GRAVEL UNDER ALL INTERIOR CONCRETE SLAB-ON-GRADE FLOORS. PROVIDE A MIN. 6 MIL VAPOR BARRIER ON TOP OF THE PEA GRAVEL FILL. PROVIDE A 2" THICK MOISTENED SAND FILL BED OVER THE VAPOR BARRIER AND UNDER THE CONCRETE SLAB. PROVIDE A 6" LAYER OF PEA GRAVEL OR COMPACTED GRAVEL FILL UNDER ALL EXTERIOR CONCRETE SLABS.
- APPROVED GRAVEL FILL CONSISTS OF WASHED, CLEAN, FREE-DRAINING GRAVEL RANGING FROM 1/4" TO 3/4" IN SIZE.
- PER IRC SECTION R802.8, PROVIDE FIRE BLOCKING AT ALL PLUMBING PENETRATIONS AND AT 10'-0" OC INTERVALS (HORIZONTALLY AND VERTICALLY) IN ALL WALLS. PROVIDE FIRE STOPS BETWEEN ALL INTERCONNECTIONS OF CONCEALED HORIZONTAL AND VERTICAL SPACES. PROVIDE FIRE STOPS IN ALL OPENINGS AROUND VENTS, PIPES, DUCTS, CHIMNEYS, FIREPLACES, AND SIMILAR OPENINGS WHICH AFFORD PASSAGE FOR FIRE AT CEILING AND FLOOR LEVELS WITH NON-COMBUSTIBLE MATERIALS. FIRE BLOCK CONCEALED SPACES BETWEEN STAIR STRINGERS AT THE TOP AND BOTTOM OF A RUN, AND BETWEEN STUDS ALONG, AND IN LINE WITH, THE RUN OF STAIRS (IF THE WALLS UNDER THE STAIRS ARE UNFINISHED). FIRE BLOCK AT ALL OPENINGS BETWEEN ATTIC SPACES AND CHIMNEY CHASSES, FOR FACTORY-BUILT CHIMNEYS, WHERE WOOD SLEEPERS ARE USED FOR STAIRING WOOD FLOORING ON FIRE-RESISTIVE FLOORS, THE SPACE BETWEEN THE FLOOR SLAB AND THE UNDERSIDE OF THE WOOD FLOORING SHALL BE FILLED WITH NON-COMBUSTIBLE MATERIAL AND FIRE-BLOCKED SO THAT THERE WILL BE NO SPACES GREATER THAN 100 SQUARE FEET. SUCH SPACES SHALL BE FILLED SOLIDLY UNDER ALL PERMANENT PARTITIONS SO THAT THERE WILL BE NO COMMUNICATION UNDER THE FLOOR BETWEEN ADJOINING ROOMS.
- PROVIDE A FIRE SEPARATION BETWEEN THE HABITABLE SPACES OF THE HOUSE AND THE GARAGE. SUCH SEPARATION AT WALLS SHALL CONSIST OF ONE LAYER OF 5/8" THICK TYPE 'X' GWB, TAPED AND FINISHED, ON THE GARAGE SIDE OF THE COMMON WALL, AND SHALL EXTEND FROM THE TOP OF THE GARAGE CONCRETE SLAB OR FOUNDATION WALL TO THE BOTTOM OF THE CEILING OR FLOOR SHEATHING, UNLESS OTHERWISE NOTED ON THE DRAWINGS. NAIL GWB TO THE STUDS (SPACED AT 16" OC), WITH 60 COATED NAILS, 1 7/8" LONG, 0.195" SHANK, 1/4" HEADS, SPACED AT 7" O.C. STAGGER PANEL JOINTS. ASSEMBLY SHALL MEET GYPSUM ASSOCIATION REQUIREMENT #WP 3605. PROTECTED CEILING ASSEMBLY SHALL CONSIST OF (2) LAYERS OF 1/2" THICK TYPE 'X' GWB APPLIED PERPENDICULAR TO THE FLOOR JOISTS ABOVE WITH ALL JOINTS BETWEEN LAYERS OFFSET 2'-0". ATTACH BASE LAYER WITH 1 1/4" TYPE "S" DRYWALL SCREWS AT 7" O.C., AND FACE LAYER WITH 1 7/8" TYPE "S" DRYWALL SCREWS AT 17" O.C., AND FACE LAYER WITH 1 1/2" TYPE "S" DRYWALL SCREWS SPACED AT 17" O.C. SHALL BE PLACED 3" BACK FROM EACH SIDE OF FACE LAYER END JOINT. TRUSS FRAMING SHALL HAVE A MINIMUM OF 20 GA CONNECTOR PLATES WITH A SAFETY FACTOR OF 4. ASSEMBLY SHALL MEET ALL GYPSUM ASSOCIATION REQ'S.
- ALL UNDER-FLOOR AREAS WITHIN THE FOUNDATION PERIMETER SHALL BE ACCESSIBLE BY AN UNOBSTRUCTED MINIMUM CLEAR OPENING OF 18" x 24". PER IRC SECTION R408.3.
- UNCONDITIONED UNDER-FLOOR AREAS SHALL BE VENTILATED BY AN APPROVED MECHANICAL MEANS, OR BY OPENINGS IN THE EXTERIOR FOUNDATION WALLS. SUCH OPENINGS SHALL HAVE A NET UNIT AREA OF NOT LESS THAN 1 SQUARE FOOT FOR EACH 150 SQUARE FEET OF UNDER-FLOOR AREA. OPENINGS SHALL HAVE AN APPROVED INSECT SCREEN, AND SHALL BE LOCATED AS CLOSE TO CORNERS AS IS PRACTICAL, AND SHALL PROVIDE CROSS-VENTILATION OF THE SPACE. THE REQUIRED AREA OF SUCH OPENINGS SHALL BE APPROXIMATELY EQUALLY DISTRIBUTED ALONG THE LENGTH OF AT LEAST TWO OPPOSITE SIDES PER IRC SECTION R408.2.
- PROVIDE A MINIMUM 22"x30" UNOBSTRUCTED ACCESS PANEL TO ALL ROOF ATTIC AREAS WITH A NET CLEAR HEIGHT OF 30" OR GREATER FROM THE TOP OF THE CEILING JOISTS TO THE BOTTOM OF THE RAFTERS PER IRC SECTION R807.1.1
- PROVIDE ATTIC VENTILATION OF 1/50 OF ATTIC AREA IF ALL VENTILATION IS LOCATED IN THE SOFFIT, OR 1/300 IF HALF OF THE REQUIRED VENTILATION IS LOCATED AT THE SOFFIT AND HALF IS LOCATED A MINIMUM OF 3'-0" ABOVE THE SOFFIT VENTILATION, OR WHERE THERE IS A CONTINUOUS PVA OR POLY FILM VAPOR BARRIER AT THE CEILING, PER IRC SECTION 806.2. SEE PLANS FOR ACTUAL CALCULATIONS AND REQUIREMENTS.
- APPLICATION AND INSTALLATION OF ALL INSULATION AND VAPOR BARRIERS SHALL COMPLY WITH ALL STATE OF WASHINGTON THERMAL INSULATION STANDARDS.
- WHEN HVAC OR WATER HEATERS ARE PLACED IN AN AREA SUSCEPTIBLE TO MOISTURE, INCLUDING BUT NOT LIMITED TO A GARAGE, ALL PILOT LIGHTS, BURNERS, SWITCHES, OR HEATING ELEMENTS SHALL BE LOCATED A MINIMUM OF 18" ABOVE THE FLOOR OR SLAB. PROVIDE SEISMIC ANCHOR STRAPS TO THE WALL FOR ALL WATER HEATERS.
- GUARDRAILS SHALL BE PLACED AT ALL UNENCLOSED FLOOR AREAS AND ROOF OPENINGS, OPEN AND GLAZED SIDES OF STAIRWAYS, LANDINGS, RAMPS, BALCONIES, DECKS OR PORCHES WHICH ARE MORE THAN 30" ABOVE GRADE OR FLOOR BELOW. THE TOP OF GUARDRAILS SHALL NOT BE LESS THAN 36" IN HEIGHT ABOVE THE FINISHED WALKING SURFACE. OPEN GUARDRAILS SHALL HAVE INTERMEDIATE RAILS OR ORNAMENTAL PATTERN SPACED SUCH THAT A 4" DIAMETER SPHERE CAN NOT PASS THROUGH. THE TRIANGULAR OPENINGS FORMED BY THE STAIR RISER/TREAD AND THE BOTTOM ELEMENT OF A GUARDRAIL AT THE OPEN SIDE OF THE STAIR MAY BE OF A SIZE SUCH THAT A 6" DIAMETER SPHERE CAN NOT PASS THROUGH, PER IRC SECTION 312.2. CONTRACTOR SHALL DEMONSTRATE TO BUILDING INSPECTOR THAT RAIL IS CAPABLE OF WITHSTANDING 200LB FORCE IN ANY DIRECTION AT THE TOP RAIL.
- PER IRC SECTION R311.5.6, ONE HANDRAIL SHALL BE PROVIDED AT EVERY STAIRWAY HAVING FOUR OR MORE RISERS. PROVIDE TWO HANDRAILS WHERE INDICATED ON THE PLANS. HANDRAILS SHALL BE CONTINUOUS FOR THE FULL LENGTH OF THE STAIRS. TOP HANDRAILS SHALL BE PLACED AT 36" ABOVE THE NOSING OF THE TREADS, BUT NOT LESS THAN 34" OR MORE THAN 38". HAND GRIP PORTION OF HANDRAILS SHALL NOT BE LESS THAN 1 1/4" NOR MORE THAN 2" IN CROSS SECTION DIMENSION. SHALL HAVE A SMOOTH SURFACE WITH NO SHARP CORNERS, AND SHALL TERMINATE INTO WALLS OR NEWEL POSTS. HANDRAILS ADJACENT TO WALLS SHALL HAVE A MINIMUM CLEARANCE OF 1 1/2" BETWEEN THE HANDRAIL AND WALL SURFACE.
- THE ROOFING INSTALLER MUST BE APPROVED BY THE ROOFING PRODUCT MANUFACTURER AND THE ARCHITECT. INSTALL ROOFING ONLY WHEN SATISFACTORY CONDITIONS PREVAIL. APPLY NO ROOFING WHEN MOISTURE IN ANY FORM IS PRESENT. INSTALL ALL ROOFING STRICTLY PER MANUFACTURER'S INSTRUCTIONS, RECOMMENDATIONS, AND SPECIFICATIONS, FLASH AND COUNTER-FLASH ALL ROOF PENETRATIONS. ROOFING SHALL CONFORM TO IRC SECTION R905.
- PROVIDE A MINIMUM 26 GA GALVANIZED STEEL FLASHING AND COUNTER-FLASHING AT ALL ROOF PENETRATIONS AND INTERSECTIONS OF ROOF PLANES TO VERTICAL SURFACES AND AT PARAPET CAPS, UNON. UNLESS OTHERWISE NOTED ON PLANS AND SPECIFICATIONS. PROVIDE SHEET METAL DRIP CAPS AND FLASHING AT ALL HORIZONTAL, INTERRUPTIONS OF SIDING, CHANGES FROM ONE SIDING MATERIAL TO ANOTHER, AND OVER ALL DOOR AND WINDOW HEADS NOT PROTECTED BY AN OVERHANG WITHIN 6" OF THE HEAD, UNLESS OTHERWISE NOTED ON PLANS AND SPECIFICATIONS.
- PER IRC SECTION R310, EGRESS SHALL BE PROVIDED FROM EACH SLEEPING ROOM. EGRESS WINDOWS SHALL BE PROVIDED WHERE DOORS WHICH EXIT DIRECTLY TO THE EXTERIOR FROM THE SLEEPING ROOM ARE NOT PROVIDED. EGRESS WINDOW UNITS SHALL HAVE A MINIMUM NET CLEAR OPENING OF 5.7 SQUARE FEET. THE MINIMUM NET CLEAR OPENING HEIGHT DIMENSION SHALL BE 24", AND THE MINIMUM NET CLEAR OPENING WIDTH SHALL BE 20". THE FINISHED SILL HEIGHT SHALL BE NO MORE THAN 44" ABOVE THE FLOOR.
- VENT ALL CLOTHES DRYERS, EXHAUST FANS, AND COOKTOP/RANGE HOODS TO THE EXTERIOR OF THE BUILDING PER IRC SECTION M1501 - M1506. EXHAUST TERMINATIONS SHALL EXIT THE STRUCTURE WITH CLEARANCES MEETING SRC M1506.3.1.3.1.3.1.
- TILE OR OTHER NON-ABSORBENT SURFACE MATERIAL FOR SHOWERS SHALL EXTEND A MINIMUM OF 72" ABOVE THE DRAIN INLET AND HAVE A WATER-RESISTANT BACKING PER IRC SECTION R307.2.
- ALL HINGED SHOWER DOORS SHALL OPEN OUTWARD.
- ALL NEW GLAZING SHALL BE IN COMPLIANCE WITH IRC SECTION R308 AND WASHINGTON STATE SAFETY GLASS LAW.
- PER IRC R308.4, GLAZING IN LOCATIONS SUBJECT TO HUMAN IMPACT SHALL BE FULLY TEMPERED GLASS, LAMINATED SAFETY GLASS, OR SHATTER-RESISTANT PLASTIC. THE FOLLOWING AREAS SHALL BE CONSIDERED SPECIFIC HAZARD AREAS: GLAZING IN SWINGING DOORS EXCEPT ALCOUSIES; GLAZING IN FIXED AND SLIDING PANELS OF SLIDING DOOR ASSEMBLIES AND PANELS IN SLIDING AND BI-FOLD DOOR ASSEMBLIES; GLAZING IN STORM DOORS; GLAZING IN ALL UNFRAMED SWINGING DOORS; GLAZING IN DOORS AND ENCLOSURES FOR HOT TUBS, WHIRLPOOLS, SAUNAS, STEAM ROOMS, BATHTUBS AND SHOWERS - OR ANY PART OF A BUILDING WALL ENCLOSES THESE COMPARTMENTS WHERE THE BOTTOM EXPOSED EDGE OF THE GLAZING IS LESS THAN 60" MEASURED VERTICALLY ABOVE ANY STANDING OR WALKING SURFACE; GLAZING WHERE THE BOTTOM EDGE IS LESS THAN 18" ABOVE THE FLOOR AND THE EXPOSED AREA OF AN INDIVIDUAL PANE IS GREATER THAN 9 SQUARE FEET AND THE EXPOSED TOP EDGE IS GREATER THAN 36" ABOVE THE FLOOR AND THERE IS ONE OR MORE WALKING SURFACES WITHIN 36" HORIZONTALLY OF THE GLAZING; GLAZING IN RAILINGS REGARDLESS OF AN AREA OR HEIGHT ABOVE A WALKING SURFACE; GLAZING IN WALLS AND FENCES INCLUDING INDOOR AND OUTDOOR SWIMMING POOLS, HOT TUBS, AND SPAS, WHERE THE BOTTOM EDGE OF THE GLAZING IS LESS THAN 60" ABOVE THE WALKING SURFACE AND IS WITHIN 60" HORIZONTALLY OF THE WATER'S EDGE; GLAZING ADJACENT TO STAIRWAYS, LANDINGS, AND RAMPS WITHIN 36" HORIZONTALLY OF THE WALKING SURFACE; GLAZING ADJACENT TO STAIRWAYS WITHIN 60" HORIZONTALLY OF THE BOTTOM TREAD.
- PER IRC SECTION R308.6.2, GLAZING IN ALL FACTORY-BUILT SKYLIGHTS SHALL BE EITHER LAMINATED GLASS WITH A .015" POLYVINYL BUTYRAL INTERLAYER, (FOR GLASS PANELS 16 SQ FT OR LESS IN AREA LOCATED SUCH THAT THE HIGHEST POINT OF THE GLASS IS NOT MORE THAN 12' ABOVE THE WALKING SURFACE), TEMPERED GLASS, HEAT-STRENGTHENED GLASS, WIRED GLASS, OR APPROVED PLASTIC. LOCATIONS IN EXCESS OF 12' FROM WALKING SURFACE THE LAMINATED GLASS INTERLAYER SHALL BE 0.030 INCHES THICK.

**CONSTRUCTION SEQUENCE:**

- SCHEDULE THE PRE-CONSTRUCTION MEETING.
- FLAG OR FENCE ALL CRITICAL AREAS AND CLEARING LIMITS.
- POST A SIGN WITH THE NAME AND PHONE NUMBER OF THE E.S.C. SUPERVISOR.
- GRADE AND INSTALL CONSTRUCTION ENTRANCE(S).
- INSTALL PERIMETER PROTECTION (SILT FENCE, BRUSH BARRIER, ETC.).
- CONSTRUCT SEDIMENT PONDS AND TRAPS, IF REQUIRED.
- GRADE AND STABILIZE CONSTRUCTION ROADS.
- CONSTRUCT SURFACE WATER CONTROLS (INTERCEPTOR DIKES, PIPE SLOPE DRAINS, ETC.) SIMULTANEOUSLY WITH CLEARING AND GRADING FOR PROJECT DEVELOPMENT.
- INSTALL UTILITIES.
- MAINTAIN EROSION CONTROL MEASURES IN ACCORDANCE WITH LOCAL STANDARDS AND MANUFACTURER'S RECOMMENDATIONS.
- RELOCATE SURFACE WATER CONTROLS OR EROSION CONTROL MEASURES, OR INSTALL NEW MEASURES SO THAT AS SITE CONDITIONS CHANGE, THE EROSION AND SEDIMENT CONTROL IS ALWAYS IN ACCORDANCE WITH THE ACCEPTED STANDARD BMP'S.
- COVER ALL AREAS THAT WILL BE UNWORKED FOR MORE THAN SEVEN DAYS DURING THE DRY SEASON OR TWO DAYS DURING THE WET SEASON WITH STRAW, WOOD FIBER MULCH, COMPOST, PLASTIC SHEETING, OR EQUIVALENT.
- STABILIZE ALL AREAS WITHIN SEVEN DAYS OF REACHING FINAL GRADE.
- SEED OR SOD ANY AREAS OF THE PROJECT, STABILIZE ALL DISTURBED AREA AND REMOVE BMP'S IFF APPROPRIATE
- UPON COMPLETION OF THE PROJECT, STABILIZE ALL DISTURBED AREAS AND REMOVE BMP'S IF APPROPRIATE.

**PRIOR TO BEGINNING CLEARING OR GRADING**

- INSTALL THE SLIT FENCE AS INDICATED ON THE SITE PLAN & SHEET C1.0
- PLACE A THICK LAYER OF STRAW OR MULCH ON ALL AREAS OF BARE SOIL OUTSIDE OF THE PLANNED NEW CONSTRUCTION. THIS IS PARTICULARLY IMPORTANT IN THE SOUTH, LOW END OF THE LOT.
- INSTALL PRE MANUFACTURED SILT SOCKS IN THE TWO EXISTING CATCH BASINS LOCATED SOUTH & EAST OF THE SITE. THIS CATCH BASIN PROTECTION MUST BE CHECKED PERIODICALLY, & CLEANED AS NECESSARY, TO PREVENT THE SILT SOCKS FROM BECOMING OVERLOADED WITH SILT & DEBRIS FROM SURFACE RUNOFF.
- CONSTRUCT A STABILIZED CONSTRUCTION ENTRANCE, AS SHOWN ON SHEET C1.0 OF THE DRAWINGS, WHEREVER TRUCKS WILL DRIVE OFF AF PAVED SURFACES TO IMPORT OR EXPORT DEBRIS & SOIL.


**DURING GRADING & CONSTRUCTION**

- COVER ANY SOIL STOCKPILES WITH PLASTIC SHEETING THAT IS STAKED OR WEIGHTED TO PREVENT IT FROM BLOWING AWAY.
- ALLOW NO RUNOFF FROM THE EXCAVATION FOR THE SOUTHERN ADDITION TO FLOW ACROSS THE GROUND SURFACE TOWARD THE SOUTH. THIS MAY REQUIRE CREATING A SOIL BERM ALONG THE SOUTHERN EDGE OF THE EXCAVATION. IF SILTY RUNOFF COLLECTS IN THE EXCAVATION, IT MAY NEED TO BE PUMPED TO A TEMPORARY HOLDING TANK FOR DISPOSAL OFF SITE.
- FOLLOWING CONSTRUCTION OF THE FOUNDATION WALLS, PROCEED IMMEDIATELY WITH INSTALLATION OF DRAINAGE & WATER PROOFING, THEN COMPLETION OF BACKFILLING.
- SPREAD STRAW OR MULCH AGAIN ON ALL BARE SOIL OUTSIDE OF THE BACKFILLED FOUNDATIONS, UNLESS PERMANENT LANDSCAPING & VEGETATION WILL BE IMMEDIATELY ESTABLISHED.

**EROSION AND SEDIMENTATION CONTROL GENERAL NOTES:**

- NOT USED
- NOT USED
- PERIMETER PROTECTION MAY BE USED AS THE SOLE FORM OR TREATMENT WHEN THE FLOWPATH MEETS THE CRITERIA LISTED BELOW. IF THESE ARE NOT MET, PERIMETER PROTECTION SHALL ONLY BE USED AS A BACKUP TO A SEDIMENT TRAP OR POND.
 


AVERAGE SLOPE	SLOPE PERCENT	FLOWPATH LENGTH
1.5H:1V OR LESS	67% OR LESS	100 FEET
2H:1V OR LESS	50% OR LESS	115 FEET
4H:1V OR LESS	25% OR LESS	150 FEET
6H:1V OR LESS	16.7% OR LESS	200 FEET
10H:1V OR LESS	10% OR LESS	250 FEET
- THE CONTRACTOR SHALL STABILIZE DENUDED AREAS AND SOIL STOCKPILES AS FOLLOWS:  
DENUDED AREAS SHALL BE COVERED BY MULCH, SOD, PLASTIC, OR OTHER BMP'S APPROVED BY THE ENGINEER. WHERE POSSIBLE NATURAL VEGETATION SHALL BE MAINTAINED FOR EROSION AND SEDIMENT CONTROL.
- AS CONSTRUCTION PROGRESSES AND SEASONAL CONDITIONS DICTATE, THE EROSION CONTROL FACILITIES SHALL BE MAINTAINED AND/OR ALTERED AS REQUIRED TO ENSURE CONTINUING EROSION/SEDIMENT CONTROL.
- EVERY EFFORT SHALL BE MADE TO CLOSE UTILITY TRENCHES BY THE END OF THE DAY AND MATERIAL EXCAVATED DURING UNDERGROUND UTILITY CONSTRUCTION SHALL BE PLACED ON THE UPHILL SIDE OF TRENCHES (WHERE CONSISTENT WITH SAFETY AND SPACE CONSIDERATIONS).
- ALL TEMPORARY EROSION AND SEDIMENT CONTROL BMP'S SHALL BE MAINTAINED IN A SATISFACTORY CONDITION UNTIL SUCH TIME THAT CLEARING AND/OR CONSTRUCTION IS COMPLETED, PERMANENT DRAINAGE FACILITIES ARE IN OPERATION, AND THE POTENTIAL FOR EROSION HAS PASSED.
- AT A MINIMUM, EROSION AND SEDIMENT CONTROL FACILITIES SHALL BE MAINTAINED MONTHLY, OR FOLLOWING EACH RUNOFF-PRODUCING STORM, TO ENSURE PROPER OPERATION OF ALL EROSION AND SEDIMENT CONTROL FACILITIES. SEDIMENT SHALL BE REMOVED FROM BMP'S WHEN IT REACHES 9-FOOT DEPTH.
- THE PUBLIC RIGHT-OF-WAY SHALL BE KEPT CLEAN. TRACKING OF MUD AND DEBRIS FROM THE SITE WILL NOT BE ALLOWED. FAILURE TO COMPLY WITH THIS CONDITION MAY RESULT IN ALL WORK ON SITE BEING STOPPED.
- THE WASHINGTON STATE CLEAN AIR ACT REQUIRES THE USE OF ALL KNOWN AVAILABLE, AND REASONABLE MEANS OF CONTROLLING AIR POLLUTION, INCLUDING DUST. DUST CAN BE CONTROLLED BY WETTING EXPOSED SOILS, WASHING TRUCK WHEELS BEFORE THEY LEAVE THE SITE, AND INSTALLING AND MAINTAINING ROCK CONSTRUCTION ENTRANCES. CONSTRUCTION VEHICLE TRACK-OUT IS A MAJOR SOURCE OF DUST AND ANY EVIDENCE OF TRACK-OUT CAN TRIGGER FINES FROM THE DEPARTMENT OF ECOLOGY OF THE PUGET SOUND AIR POLLUTION CONTROL AGENCY.
- NOT USED
- THE CONTRACTOR SHALL REMOVE ALL TEMPORARY EROSION AND SEDIMENTATION CONTROL BMP'S WITHIN 30 DAYS AFTER FINAL SITE STABILIZATION OR AFTER THEY ARE NO LONGER NECESSARY.



**HECKMAN architects**

501 ROY ST. STE C232  
SEATTLE, WA 98109


Arheckman@gmail.com  
(206) 478-6850  
HECKMANarchitects.com




All Rights Reserved © 2024

**FONG ADDITION**  
8801 SE 56TH STREET  
MERCER ISLAND, WA 98040

**EROSION CONTROL  
DETAILS AND NOTES**



- NOTES:**
- INSTALL THE SILT FENCE FIRST. AFTER THE SILT FENCE HAS BEEN INSTALLED, CONSTRUCT BERM AND TRENCH.
  - THE FILTER FABRIC SHALL BE PURCHASED IN A CONTINUOUS ROLL CUT TO THE LENGTH OF THE BARRIER TO AVOID THE USE OF JOINTS. WHEN JOINTS ARE NECESSARY, THE FILTER FABRIC SHALL BE SPUNCE TOGETHER ONLY AT A SUPPORT POST, WITH A MINIMUM 6 INCH OVERLAP, AND BOTH ENDS SHALL BE SECURELY FASTENED TO THE POST.
  - POSTS SHALL BE SPACED A MAXIMUM OF 6 FEET APART AND DRIVEN SECURELY INTO THE GROUND A MINIMUM OF 30 INCHES (WHERE PHYSICALLY POSSIBLE).
  - A TRENCH SHALL BE EXCAVATED APPROXIMATELY 8 INCHES WIDE AND 12 INCHES DEEP ALONG THE LINE OF POSTS AND UPSLOPE FROM THE BARRIER. THE TRENCH SHALL BE CONSTRUCTED TO FOLLOW THE CONTOUR. 20 INCHES OF THE FILTER FABRIC SHALL EXTEND INTO THE TRENCH AND THE TRENCH SHALL BE BACKFILLED WITH COMPACTED NATIVE SOIL MATERIAL.
  - THE FILTER FABRIC FENCE SHALL NOT EXTEND MORE THAN 36 INCHES ABOVE THE ORIGINAL GROUND SURFACE. FILTER FABRIC SHALL NOT BE STAPLED TO EXISTING TREES.
  - WHEN SILT FILM FILTER FABRIC IS USED, A WIRE MESH SUPPORT FENCE SHALL DUTY WIRE STAPLES AT LEAST 1 INCH LONG, THE WIRES, OR HOG RINGS. THE WIRE SHALL EXTEND INTO THE TRENCH A MINIMUM OF 4 INCHES. SILT FILM FILTER SHALL BE WIRED TO THE FENCE.
  - WHEN EXTRA-STRENGTH OR MONOFILAMENT FABRIC IS USED, THE WIRE MESH SUPPORT FENCE MAY BE ELIMINATED. IN THIS CASE, THE FILTER FABRIC IS STAPLED OR WIRED DIRECTLY TO THE POSTS. EXTRA CARE SHOULD BE USED WHEN JOINING OR OVERLAPPING THESE STIFFER FABRICS.



**SILT FENCE DETAIL**  
SCALE: N.T.S.


**COVER MEASURES**

COVER METHODS INCLUDE THE USE OF MULCH, EROSION CONTROL NETS AND BLANKETS, PLASTIC COVERING, SEEDING, AND SODDING. MULCH AND PLASTIC SHEETING ARE PRIMARILY INTENDED TO PROTECT DISTURBED AREAS FOR A SHORT PERIOD OF TIME, TYPICALLY DAYS TO A FEW MONTHS. SEEDING AND SODDING ARE MEASURES FOR AREAS THAT ARE TO REMAIN UNWORKED FOR MONTHS.


TEMPORARY EROSION CONTROL SEED MIX:			
	% WEIGHT	% PURITY	% GERMINATION
ANNUAL OR PERENNIAL RYE (LOLIUM MULTIFLORUM OR LOLIUM PERENNE)	40	98	90
REDTOP OR COLONIAL BENTGRASS (AGROSTIS ALBA OR AGROSTIS TENUIS)	10	92	85

PERMANENT SEED MIX:				
	% WEIGHT	% PURITY	% GERMINATION	REMARKS
PERENNIAL RYE BLEND (LOLIUM PERENNE)	70	98	90	THIS MIX IS PROVIDED AS JUST ONE RECOMMENDED POSSIBILITY. LOCAL SUPPLIERS SHOULD BE CONSULTED FOR THEIR RECOMMENDATIONS BECAUSE THE APPROPRIATE MIX DEPENDS ON A VARIETY OF FACTORS, INCLUDING EXPOSURE, SOIL TYPE, SLOPE, AND EXPECTED FOOT TRAFFIC.
CHEWINGS AND RED FESCUE BLEND (FESTUCA RUBRA VAR. COMMUTATA OR FESTUCA RUBRA)	30	98	90	

MULCH STANDARDS AND GUIDELINES:			
MULCH MATERIAL	QUALITY STANDARDS	APPLICATION RATES	REMARKS
STRAW	AIR-DRIED, FREE FROM UNDESIRABLE SEED AND COARSE MATERIAL.	2"-3" THICK; 2-3 BALES PER 1000 SF OR 2-3 TONS PER ACRE	COST-EFFECTIVE PROTECTION WHEN APPLIED WITH ADEQUATE THICKNESS. HAND-APPLICATION GENERALLY REQUIRES GREATER THICKNESS THAN BLOWN STRAW. STRAW SHOULD BE CRIMPED TO AVOID WIND BLOW. THE THICKNESS OF STRAW MAY BE REDUCED BY HALF WHEN USED IN CONJUNCTION WITH SEEDING.
CHIPPED SITE VEGETATION	AVERAGE SIZE SHALL BE SEVERAL INCHES.	2" MINIMUM THICKNESS	THIS IS A COST-EFFECTIVE WAY TO DISPOSE OF DEFRIS FROM CLEARING AND GRUBBING, AND IT ELIMINATES THE PROBLEMS ASSOCIATED WITH BURNING. GENERALLY, IT SHOULD NOT BE USED ON SLOPES ABOVE APPROXIMATELY 10% BECAUSE OF ITS TENDENCY TO BE TRANSPORTED BY RUNOFF. IT IS NOT RECOMMENDED WITHIN 200 FEET OF SURFACE WATERS. IF SEEDING IS EXPECTED SHORTLY AFTER MULCH, THE DECOMPOSITION OF THE CHIPPED VEGETATION MAY TIE UP NUTRIENTS IMPORTANT TO GRASS ESTABLISHMENT.



- MINIMUM SIX (6) FOOT HIGH TEMPORARY, CONTINUOUS CHAIN LINK FENCE SHALL BE PLACED AT THE CRITICAL ROOT ZONE OR DESIGNATED LIMIT OF DISTURBANCE OF THE TREE TO BE SAVED. FENCE SHALL COMPLETELY ENIRCLE SIGNIFICANT EXISTING TREE(S). INSTALL CONTINUOUS CHAIN LINK FENCING POST(S) USING PIER BLOCK ONLY AT MAXIMUM 10 (TEN) FEET O.C. AVOID POST OR STAKES INTO MAJOR ROOTS. MODIFICATIONS TO FENCING MATERIAL AND LOCATION MUST BE APPROVED BY PLANNING OFFICIAL.
- TREATMENT OF ROOTS EXPOSED DURING CONSTRUCTION: FOR ROOTS OVER ONE (1) INCH DIAMETER DAMAGED DURING CONSTRUCTION, MAKE A CLEAN STRAIGHT CUT TO REMOVE DAMAGED PORT OF ROOT, ALL EXPOSED ROOTS SHALL BE TEMPORARILY COVERED WITH DAMP BURLAP TO PREVENT DRYING AND COVERED WITH SOIL AS SOON AS POSSIBLE.
- NO STOCKPILING OF MATERIALS, VEHICULAR TRAFFIC, OR STORAGE OF EQUIPMENT OR MACHINERY SHALL BE ALLOWED WITHIN THE LIMIT OF THE FENCING. FENCING SHALL NOT BE MOVED OR REMOVED UNLESS APPROVED BY THE CITY PLANNING OFFICIAL. WORK WITHIN PROTECTION FENCE SHALL BE DONE MANUALLY UNDER THE SUPERVISION OF THE ON-SITE ARBORIST AND WITH PRIOR APPROVAL BY THE CITY PLANNING OFFICIAL.
- A PRINTED TREE PROTECTION AREA SIGN NOTING "TREE PROTECTION AREA - ENTRANCE PROHIBITED. TO REPORT VIOLATIONS, CONTACT CITY CODE ENFORCEMENT AT 425-587-3600.", MUST BE POSTED ALONG THE FENCE EVERY FIFTEEN (15) FEET. PRINT AND LAMINATE THE TREE PROTECTION AREA SIGN(PDF, 54KB) AND POST ON SITE.



REVISIONS:  
10/29/24 PERMIT RESPONSE

PERMIT INTAKE DATE:  
07/17/2024

PLOT DATE:  
10/29/2024

SHEET NUMBER:  
**C1.0**

www.HECKMANarchitects.com



# FLOOR PLAN NOTES

- NEW PARTITION CONSTRUCTION SHOWN POCHED.
- ALL DIMENSIONS TO F.O. FRAMING UNO.
- 'FIN' INDICATES DIMENSION TO FINISH.
- REFER TO SHEETS T1.0 & T1.1 FOR ADDITIONAL NOTES, LEGENDS, SYMBOLS, ABBREVIATIONS, & SCHEDULES.
- PATCH/REPAIR, PRIME & PAINT ALL EXISTING GWB WALLS TO REMAIN.
- PARTITIONS THAT ARE NOT DIMENSIONED ARE TO BE LOCATED FLUSH & SQUARE WITH THE EXISTING PARTITION.
- WALLS THAT APPEAR TO ALIGN DO ALIGN. WALLS THAT APPEAR CENTERED ON COLUMNS ARE CENTERED ON COLUMNS.
- \*ALIGN\* MEANS TO ACCURATELY LOCATE THE FINISHED FACES IN THE SAME PLANE.
- NOTIFY ARCHITECT IN WRITING OF ANY DISCREPANCIES OR CONFLICTS IN THE LOCATION(S) OF NEW CONSTRUCTION. UPON COMPLETION OF PARTITION LAYOUT, NOTIFY ARCHITECT. ALLOW TIME IN THE SCHEDULE FOR VERIFICATION OF THE LAYOUT BY THE ARCHITECT PRIOR TO PARTITION INSTALLATION.
- ALL DOORS TO BE 4" FROM ADJACENT WALL TO INT. F.O. FINISHED JAMB. UNO. DIMENSIONS LOCATING DOORS ARE TO FINISHED OPENING. UNO.
- ALL WORK SHALL BE ERRECTED & INSTALLED PLUMB, LEVEL, SQUARE & TRUE.
- ALL INTERIOR WALLS NOT LABELED WITH WALL TAG ARE INFILL WALLS TO MATCH EXISTING PARTITION.
- ALL HANDRAILS TO BE 1 1/4" DIA., LOCATED 1 1/2" MIN. FROM ADJACENT WALL ON AT LEAST ONE SIDE OF STAIRS AND SHALL RETURN TO WALL AT ENDS.
- ALL HANDRAILS TO BE 34 - 38" HIGH ABV. STAIR NOSE.
- ALL GUARDRAILS TO BE 36" HIGH WITH CABLE RAILS INSTALLED AND TENSIONED TO ALLOW A 4" MAX. CLEAR SPACE BETWEEN RAILS.
- ALL TREADS TO HAVE 1" NOSING.
- WHERE EXISTING FRAMING REMAINS AND THE FRAMING CAVITY IS EXPOSED DURING CONSTRUCTION, THE CAVITY MUST BE FILLED WITH INSULATION: MIN R-15 FOR 2x4 FRAMED WALLS, MIN R-21 FOR 2x6 FRAMED WALLS.
- FOR NEW FRAMED ABOVE-GRADE WALLS, INSTALL MIN. INSULATION OF R-20 STUD CAVITY INSULATION PLUS CONTINUOUS R-5 RIGID INSULATION AT EXTERIOR FACE OF WALL SHEATHING AND R-10 AT HEADERS.
- FOR NEW BELOW-GRADE WALLS, INSTALL MIN. INSULATION OF R-10 CONTINUOUS ON OUTSIDE OF WALL OR R-15 CONTINUOUS ON INSIDE OF WALL OR R-21 STUD CAVITY INSULATION + R-10 AT HEADERS + THERMAL BREAK BETWEEN SLAB AND BELOW-GRADE WALL OR R-13 STUD CAVITY INSULATION + R-5 CONTINUOUS INSULATION ON INSIDE OR OUTSIDE OF WALL.
- FOR NEW WINDOWS AND GLAZED DOORS, PROVIDE MAX. U-FACTOR OF 0.30 UNLESS NOTED OTHERWISE IN THE PLAN SET.

## WALL PARTITIONS:



- TYPICAL EXTERIOR WALL**  
EXTERIOR WALL FINISH OF CONT. R-5 RIGID INSUL. OR WATER-RESISTIVE BARRIER OF 1/2" CDX PLYWOOD OF 2x6 WOOD STUDS AT 16" OC OF 1/2" GWB AT INTERIOR W/ R-20 CRAFT-FACE BATT INSUL.
- TYPICAL INTERIOR PARTITION**  
U.N.O. ALL INTERIOR WALL SHALL BE 2x4 WOOD STUDS @ 16" O.C. W/ 1/2" GYPSUM WALLBOARD EACH SIDE.
- 1HR. FIRE RATED WALL**  
1/2" THK GWB OF 2x6 WD STUDS @ 16" O.C. PANELS NAILED 7" O.C. - 1 7/8" CEM CTD WALLS. JOINTS EXP OR FIN. - PERIM CAULKED - UL DES U305 & U314 - JOINTS FIN.
- SOUND PROOF 2x6 STUD WALL**  
2x6 SILL & TOP PLATES AND STAGGERED 2x4 VERTICAL STUDS @ 8" OC W/ INTER-WOVEN SOUNDS BATTS W/ GYPSUM WALLBOARD EACH SIDE.

## FLOOR PLAN LEGEND

- EXISTING WALL
- NEW WALL
- NEW ADDITION
- EXHAUST FAN: 50 CFM MIN. FOR BATHROOM AND LAUNDRY; 100 CFM MIN. FOR KITCHEN; COORDINATE SPECS W/ WHOLE HOUSE VENTILATION REQUIREMENTS (SEE G0.00); MIN. AIR INTAKE OPENINGS = 4 IN² PER ROOM
- HARDWIRED SMOKE DETECTOR W/ BATTERY BACKUP
- HEAT DETECTOR
- HARDWIRED CARBON MONOXIDE DETECTOR W/ BATTERY BACKUP
- TEMPERED GLAZING
- EGRESS WINDOW

# UPPER FLOOR PLAN

SCALE: 1/4" = 1'-0"



## HECKMAN architects

501 ROY ST, STE C232  
SEATTLE, WA 98109

anheckman@gmail.com  
(206) 478-6850  
HECKMANarchitects.com



All Rights Reserved © 2024

**FONG ADDITION**  
8801 SE 56TH STREET  
MERCER ISLAND, WA 98040

**UPPER FLOOR PLAN**

REVISIONS:	10/29/24 PERMIT RESPONSE
PERMIT INTAKE DATE:	07/17/2024
PLOT DATE:	10/29/2024
SHEET NUMBER:	

# A2.1

www.HECKMANarchitects.com

**WINDOW SCHEDULE**

WINDOW MARK	DESCRIPTION	R.O. SIZE		TEMP.	QTY.	U-VALUE (MIN.)	GLAZING	REMARKS & NOTES
		WIDTH	HEIGHT					
A	FIXED	5'-0"	3'-6"	-	1	0.25	LOW E/ CLEAR	
B	FIXED	2'-0"	3'-6"	-	3	0.25	LOW E/ CLEAR	
C	SLIDING	4'-0"	3'-6"	-	1	0.25	LOW E/ CLEAR	
D	FIXED	2'-6"	2'-0"	Y	1	0.25	LOW E/ CLEAR	
E	SLIDING	5'-0"	3'-6"	Y	1	0.25	LOW E/ CLEAR	
F	AWNING	2'-6"	2'-0"	-	1	0.25	LOW E/ CLEAR	
G	SLIDING	6'-0"	3'-6"	-	3	0.25	LOW E/ CLEAR	
H	SLIDING	10'-0"	3'-6"	-	1	0.25	LOW E/ CLEAR	EGRESS PER PLANS
J	FIXED	± 2'-6"	3'-6"	-	1	0.25	LOW E/ CLEAR	MATCH EX. WINDOW WIDTH BELOW
K	FIXED	9'-0"	2'-0"	-	1	0.25	LOW E/ CLEAR	


**DOOR SCHEDULE**

DOOR NO.	LOCATION	SIZE WIDTH	SIZE HEIGHT	DOOR TYPE	DOOR FIN.	DOOR THK.	U-VAL. (MIN.)	DOOR HDWR.	REMARKS
<b>LOWER FLOOR</b>									
101	CLOSET	2'-6"	± 6'-8"	A	PNT.	1-3/4"	0.25	-	MATCH EX. DOOR HEIGHT
<b>MAIN FLOOR</b>									
201	P BATH TOILET	2'-6"	7'-0"	A	PNT.	1-3/4"	-	-	
202	P BATH	2'-6"	7'-0"	B	PNT.	1-3/4"	-	-	
203	P CLOSET 1	2'-6"	7'-0"	B	PNT.	1-3/4"	-	-	
204	P CLOSET 2	2'-6"	7'-0"	B	PNT.	1-3/4"	-	-	
205	P BEDROOM	2'-8"	7'-0"	A	PNT.	1-3/4"	-	-	
206	OFFICE 2	4'-4"	7'-0"	C	PNT.	1-3/4"	-	-	


**SCHEDULE NOTES**

- CONTRACTOR TO VERIFY ALL GLAZING SIZING, AND DOOR DIMENSIONS IN FIELD PRIOR TO ROUGH FRAMING & ORDERING OF GLAZING/WINDOW/DOOR MATERIALS. REVIEW SIZES AND ANY DISCREPANCIES W/ ARCHITECT.
- ALL GLAZING TO BE "LOW E", INSULATED GLASS UNLESS NOTED OTHERWISE.
- ALL OPERABLE WINDOWS TO HAVE SCREENS.
- GLAZING INDOORS AND/OR WITHIN 24" OF A DOOR TO BE TEMPERED. SEE EXTERIOR ELEVATION FOR TEMP. GLASS LOCATION & EGRESS WINDOWS.
- 2021 WSEC & VIAQ RESIDENTIAL PRESCRIPTIVE OPTION 3 ADOPTED. GLAZING AREA INDICATED UNLIMITED. SEE ENERGY NOTE ON SHEET T1.0 FOR DETAILS.
- ALL NEW FENESTRATION ARE TO BE NFRC CERTIFIED.
- ALL WINDOW AND DOOR HEADERS ARE TO BE INSULATED WITH A MINIMUM OF R-10 INSULATION.
- VERIFY ALL EXISTING ROUGH OPENINGS PRIOR TO ORDERING WINDOWS.
- CONTRACTOR TO PROVIDE WIND PRESSURE RATING FOR GARAGE DOORS PER IRC R609.4.1.

**DOOR TYPES**



DESCRIPTION	SF AREA	REQ. VENTING PER SF AREA		VENT TYPE		VENT L.F.	TOTAL VENT AREA SQ. IN.	SF CONVERT. 1/144	80% EFF FACTOR	TOTAL
		160	300	RIDGE	SOFFIT					
		X	=	X	X					
LOWER ROOF		0.00		12 SQ. IN./FT. CONTINUOUS	18 SQ. IN./FT. 1.5" VENT					0.00
UPPER ROOF	1080	7.20		12 SQ. IN./FT. CONTINUOUS	18 SQ. IN./FT. 1.5" VENT	71	1278	8.88	7.10	9.77
						40	480	3.33	2.67	




**ROOF LEGEND**

- NEW ROOF
- MAIN FLOOR WALL LINE BELOW
- UPPER FLOOR WALL LINE BELOW

**ROOF NOTES**

- STANDING SEAM METAL ROOF, TYP.
- TIGHTLINE ALL DOWNSPOUTS TO STORM DRAINAGE SYSTEM PER CIVIL, TYP.
- TO INSURE PROPER CROSS VENTILATION IN OVER-FRAMED ROOF SPACE, DRILL (2) 1" HOLES INTO PLYWOOD SHEATHING AT EACH ROOF RAFTER BAY AS REQUIRED TO PROVIDE CLEAR AIR PATH FROM SOFFIT VENTS TO RIDGE VENTS.
- A PERMANENT CERTIFICATE INDICATING THE SRZ AND OTHER SOLAR READY PROVISIONS, WILL BE POSTED NEAR THE ELECTRICAL DISTRIBUTION PANEL, WATER HEATER, OR OTHER CONSPICUOUS LOCATION.






**LEGEND**

- T TEMPERED GLAZING
- E EGRESS WINDOW

**HECKMAN**  
architects

501 ROY ST, STE C232  
SEATTLE, WA 98109


Aheckman@gmail.com  
(206) 478-6850  
HECKMANArchitects.com




All Rights Reserved © 2024

**FONG ADDITION**  
8801 SE 56TH STREET  
MERCER ISLAND, WA 98040

**EXTERIOR ELEVATIONS**



**1 EAST ELEVATION**  
SCALE: 1/4" = 1'-0"



**2 SOUTH ELEVATION**  
SCALE: 1/4" = 1'-0"

REVISIONS:	10/29/24 PERMIT RESPONSE
1	
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	
13	
14	
15	
16	
17	
18	
19	
20	
21	
22	
23	
24	
25	
26	
27	
28	
29	
30	

PERMIT INTAKE DATE: 07/17/2024  
PLOT DATE: 10/29/2024

SHEET NUMBER: **A3.0**

www.HECKMANArchitects.com




**LEGEND**

- T TEMPERED GLAZING
- E EGRESS WINDOW

**HECKMAN**  
architects

501 ROY ST, STE C232  
SEATTLE, WA 98109

Aheckman@gmail.com  
**(206) 478-6850**  
HECKMANarchitects.com



All Rights Reserved © 2024

**FONG ADDITION**  
8801 SE 56TH STREET  
MERCER ISLAND, WA 98040

**EXTERIOR ELEVATIONS**

NO.	DESCRIPTION	DATE
1	ISSUED FOR PERMIT	07/17/2024
2	PERMIT INTAKE	07/17/2024
3	REVISIONS	
4	REVISIONS	
5	REVISIONS	
6	REVISIONS	
7	REVISIONS	
8	REVISIONS	
9	REVISIONS	
10	REVISIONS	


PERMIT INTAKE DATE:  
07/17/2024

PLOT DATE:  
7/17/2024


SHEET NUMBER:

**A3.1**

www.HECKMANarchitects.com



**3 WEST ELEVATION**  
SCALE: 1/4" = 1'-0"




**4 NORTH ELEVATION**  
SCALE: 1/4" = 1'-0"



**HECKMAN**  
architects

501 ROY ST, STE C232  
SEATTLE, WA 98109

Aheckman@gmail.com  
(206) 478-6850  
HECKMANarchitects.com



All Rights Reserved © 2024

**FONG ADDITION**  
8801 SE 56TH STREET  
MERCER ISLAND, WA 98040

**BUILDING SECTION**

REVISIONS:

1	
2	
3	
4	
5	
6	
7	
8	
9	
10	


PERMIT INTAKE DATE:  
07/17/2024

PLOT DATE:  
7/17/2024





SHEET NUMBER:

**A4.0**

www.HECKMANarchitects.com



**A BUILDING SECTION**  
SCALE: 3/4" = 1'-0"







**1** **TYPICAL DETAIL AT ROOF EAVE**  
SCALE: 1 1/2" = 1'-0"

**2** **TYPICAL DETAIL AT ROOF RAKE**  
SCALE: 1 1/2" = 1'-0"

**3** **TYPICAL DETAIL AT ROOF RIDGE VENT**  
SCALE: 1 1/2" = 1'-0"

**4** **TYPICAL WINDOW HEAD DETAIL**  
SCALE: 3" = 1'-0" SIM. AT JAMB



**5** **HANDRAIL DETAIL**  
SCALE: 6" = 1'-0"

**6** **FLASHING DETAIL AT FLUSH GRADE**  
SCALE: 6" = 1'-0"

**7** **FLASHING DETAIL AT EXT. DOOR**  
SCALE: 6" = 1'-0"


**8** **TYPICAL WINDOW SILL DETAIL**  
SCALE: 3" = 1'-0"

**FONG ADDITION**  
8801 SE 56TH STREET  
MERCER ISLAND, WA 98040

**ARCHITECTURAL DETAILS**

REVISIONS:


PERMIT INTAKE DATE: 07/17/2024  
PLOT DATE: 7/17/2024  
SHEET NUMBER:



711 Saint Helens Suite #208  
Tacoma, WA  
253.448.7331  
Jordan@JPJonesEngineering.com

DRAWN: JPJ

DESIGN: JPJ



REVISIONS:

REV NO	DESCR.	DATE

PROJECT TITLE:

Fong Section Story Addition  
8801 SE 56th Street  
Mercer Island, WA

ARCHITECT:

Heckman Architect  
501 Roy St, STE 232C  
Seattle, WA 98109  
AnHeckman@gmail.com  
206.478.6850

ISSUE:

**CONSTRUCTION**

SHEET TITLE:

Cover Sheet

SHEET SIZE: 24"x36"

SCALE:

DATE: 10-30-2024

SHEET NO:

**S1.0**

## BUILDING DESCRIPTION

Existing house is a single level wood framed house located on Mercer Island, WA. The existing house is typical residential construction with poured concrete foundations, wood stud walls, and roof trusses. The project involves adding a second level over the central portion of the house. The addition will be composed of typical wood framing including pre-manufactured floor trusses, wood stud walls, and pre-manufactured wood roof trusses. There are also some modifications to the lower level wall that separates the kitchen from living room.

## SHEET INDEX

Sheet Number	Sheet Name
S1.0	Cover Sheet
S1.1	General Structural Notes
S2.0	Foundation & Main Floor Framing Plan
S2.1	Upper Floor Framing Plan
S2.2	Roof Framing Plan
S3.0	Foundation & Framing Details
S3.1	Wall Framing Details

## ABBREVIATIONS

ABBREVIATION	WORD
EXO	EXISTING
AB	ANCHOR BOLT
ABV	ABOVE
APPROX	APPROXIMATELY
BT	BETWEEN
BAR	REINFORCING STEEL BAR
BLW	BELOW
CL	CENTER LINE
CLR	CLEAR DISTANCE
CONCR	CONCRETE
CONT	CONTINUOUS
DIA	DIAMETER
EQ	EQUAL
EXT	EXTERIOR
FOC	FACE OF CONCRETE
FOS	FACE OF STEEL
FTG	FOOTING
GALV	GALVANIZED
GLB	GLULAM BEAM
GWB	GYPSON WALL BOARD
HORIZ	HORIZONTAL
HSS	HOLLOW STRUCTURAL SECTION
INT	INTERIOR
MAX	MAXIMUM
MIN	MINIMUM
NTS	NOT TO SCALE
OC	ON CENTER (SPACING)
PT	PRESSURE TREATED
SF	SQUARE FEET
SIM	SIMILAR
TS	TUBE STEEL
TYP	TYPICAL
UNO	UNLESS OTHERWISE NOTED
VERT	VERTICAL
VIF	VERIFY IN FIELD
W	WITH

# Fong Second Story Addition

8801 SE 56th Street  
Mercer Island, WA

**CRITERIA**

ALL MATERIALS, WORKMANSHIP, AND DESIGN SHALL COMPLY WITH THE APPLICABLE BUILDING CODES, REGULATIONS, AND STANDARDS, INCLUDING IBC 2021, NDS 2018 (WOOD), AND ACI 318-19 (CONCRETE).

**DESIGN CRITERIA:**

**CODES:**  
 STRUCTURAL: IBC 2021  
 LOADING: ASCE 7-16  
 WOOD: NDS 2018  
 CONCRETE: ACI 318-19

**OCCUPANCY:**  
 RISK CATEGORY II

**SEISMIC LOAD SUMMARY:**  
 ANALYSIS PROCEDURE: EQUIVALENT LATERAL FORCE  
 LATERAL SYSTEM: WOOD STRUCTURAL PANELS  
 R = 6.5  
 Cd = 4  
 Ie = 1.0

**WIND LOAD SUMMARY:**  
 V = 98mph  
 Kzt = 1.0 (calculated)

**DEAD LOAD SUMMARY:**  
 ROOF = 15psf  
 FLOOR = 10psf

**LIVE LOAD SUMMARY:**  
 SNOW = 25psf  
 LIVE = 40psf

**GEOTECHNICAL**

- FOUNDATION NOTES: ALLOWABLE SOIL PRESSURE AND LATERAL EARTH PRESSURE ARE ASSUMED AND THEREFORE MUST BE VERIFIED BY A QUALIFIED SOILS ENGINEER OR APPROVED BY THE BUILDING OFFICIAL. IF SOILS ARE FOUND TO BE OTHER THAN ASSUMED, NOTIFY THE STRUCTURAL ENGINEER FOR POSSIBLE FOUNDATION REDESIGN.
- FOOTINGS SHALL BEAR ON FIRM, UNDISTURBED EARTH AT LEAST 18" BELOW ADJACENT FINISHED GRADE. UNLESS OTHERWISE NOTED, FOOTINGS SHALL BE CENTERED BELOW COLUMNS OR WALLS ABOVE.
- ALLOWABLE SOIL PRESSURE..... 1,500 PSF

**CONCRETE**

- CONCRETE SHALL BE MIXED, PROPORTIONED, CONVEYED AND PLACED IN ACCORDANCE WITH ACI 301, INCLUDING TESTING PROCEDURES. CONCRETE SHALL ATTAIN A 28-DAY STRENGTH OF  $f_c = 3,000$  PSI AND MIX SHALL CONTAIN NOT LESS THAN 5-1/2 SACKS OF CEMENT PER CUBIC YARD AND SHALL BE PROPORTIONED TO PRODUCE A SLUMP OF 5" OR LESS. REQUIRED CONCRETE STRENGTH IS BASED ON THE DURABILITY REQUIREMENTS OF SECTION 1904 OF THE IBC. DESIGN STRENGTH IS  $f_c = 2,500$  PSI.
- A CONCRETE PERFORMANCE MIX SHALL BE SUBMITTED TO THE STRUCTURAL ENGINEER AND THE BUILDING DEPARTMENT FOR APPROVAL TWO WEEKS PRIOR TO PLACING ANY CONCRETE. THE PERFORMANCE MIX SHALL INCLUDE THE AMOUNTS OF CEMENT, FINE AND COARSE AGGREGATE, WATER AND ADMIXTURES AS WELL AS THE WATER CEMENT RATIO, SLUMP, CONCRETE YIELD AND SUBSTANTIATING STRENGTH DATA IN ACCORDANCE WITH ACI 318-14, SECTIONS 26.4.3 AND 26.4.4. THE USE OF A PERFORMANCE MIX REQUIRES BATCH PLANT INSPECTION, THE COST OF WHICH SHALL BE PAID BY THE GENERAL CONTRACTOR. REVIEW OF MIX SUBMITTALS BY THE ENGINEER OF RECORD INDICATES ONLY THAT INFORMATION PRESENTED CONFORMS GENERALLY WITH CONTRACT DOCUMENTS. CONTRACTOR OR SUPPLIER MAINTAINS FULL RESPONSIBILITY FOR SPECIFIED PERFORMANCE.
- ALL CONCRETE WITH SURFACES EXPOSED TO WEATHER OR STANDING WATER SHALL BE AIR-ENTRAINED WITH AN AIR-ENTRAINING AGENT CONFORMING TO ASTM C260, C494, AND C618. TOTAL AIR CONTENT FOR FROST-RESISTANT CONCRETE SHALL BE IN ACCORDANCE WITH ACI 318-14, TABLE 19.3.2.1 MODERATE EXPOSURE, F1.
- REINFORCING STEEL SHALL CONFORM TO ASTM A615 (INCLUDING SUPPLEMENT S1), GRADE 60,  $F_y = 60,000$  PSI.

**WOOD**

- FRAMING LUMBER SHALL BE S-DRY, KD, OR MC-19, AND GRADED AND MARKED IN CONFORMANCE WITH WCLB STANDARD "GRADING RULES FOR WEST COAST LUMBER NO. 17", OR WWPA STANDARD, "WESTERN LUMBER GRADING RULES 2011". FURNISH TO THE FOLLOWING MINIMUM STANDARDS:
 

JOISTS (2X & 3X MEMBERS) AND BEAMS	HEM-FIR NO. 2 MINIMUM BASE VALUE, $F_b = 850$ PSI
(4X MEMBERS)	DOUGLAS FIR-LARCH NO. 1 MINIMUM BASE VALUE, $F_b = 1000$ PSI
BEAMS (INCL. 6X AND LARGER)	DOUGLAS FIR-LARCH NO. 1 MINIMUM BASE VALUE, $F_b = 1350$ PSI
POSTS (4X MEMBERS)	DOUGLAS FIR-LARCH NO. 2 MINIMUM BASE VALUE, $F_c = 1350$ PSI
(6X AND LARGER)	DOUGLAS FIR-LARCH NO. 1 MINIMUM BASE VALUE, $F_c = 1000$ PSI
STUDS, PLATES & MISC. FRAMING:	DOUGLAS-FIR-LARCH OR HEM-FIR NO. 2

- PREFABRICATED CONNECTOR PLATE WOOD ROOF TRUSSES SHALL BE DESIGNED BY THE MANUFACTURER IN ACCORDANCE WITH THE "NATIONAL DESIGN STANDARD FOR METAL PLATE-CONNECTED WOOD TRUSS CONSTRUCTION, ANSI/TPI 1" BY THE TRUSS PLATE INSTITUTE FOR THE SPANS AND CONDITIONS SHOWN ON THE PLANS. LOADING SHALL BE AS FOLLOWS:

TOP CHORD LIVE LOAD	25 PSF
TOP CHORD DEAD LOAD	10 PSF
BOTTOM CHORD DEAD LOAD	5 PSF
TOTAL LOAD	40 PSF
WIND UPLIFT (TOP CHORD)	5 PSF
BOTTOM CHORD LIVE LOAD	10 PSF
(BOTTOM CHORD LIVE LOAD DOES NOT ACT CONCURRENTLY WITH THE ROOF LIVE LOAD)	

WOOD TRUSSES SHALL UTILIZE APPROVED CONNECTOR PLATES (GANGNAIL OR EQUAL). SUBMIT SHOP DRAWINGS AND DESIGN CALCULATIONS TO THE ARCHITECT, STRUCTURAL ENGINEER, AND THE CITY OF MERCER ISLAND BUILDING PERMIT DEPARTMENT FOR REVIEW PRIOR TO FABRICATION. SUBMITTED DOCUMENTS SHALL BE SIGNED AND STAMPED BY A STRUCTURAL ENGINEER REGISTERED IN THE STATE OF WASHINGTON. PROVIDE FOR SHAPES, BEARING POINTS, INTERSECTIONS, HIPS, VALLEYS, ETC., SHOWN ON THE DRAWINGS. EXACT COMPOSITION OF SPECIAL HIP, VALLEY, AND INTERSECTION AREAS (USE OF GIRDER TRUSSES, JACK TRUSSES, STEP-DOWN TRUSSES, ETC.) SHALL BE DETERMINED BY THE MANUFACTURER UNLESS SPECIFICALLY INDICATED ON THE PLANS. PROVIDE ALL TRUSS TO TRUSS AND TRUSS TO GIRDER TRUSS CONNECTION DETAILS AND REQUIRED CONNECTION MATERIALS. PROVIDE FOR ALL TEMPORARY AND PERMANENT TRUSS BRACING AND BRIDGING.

- PLYWOOD SHEATHING SHALL BE GRADE C-D, EXTERIOR GLUE OR STRUCTURAL II, EXTERIOR GLUE IN CONFORMANCE WITH DOC PS 1 OR PS 2. ORIENTED STRAND BOARD OF EQUIVALENT THICKNESS, EXPOSURE RATING AND PANEL INDEX MAY BE USED IN LIEU OF PLYWOOD.

ROOF SHEATHING SHALL BE 1/2" (NOMINAL) WITH SPAN RATING 32/16.

WALL SHEATHING SHALL BE 1/2" (NOMINAL) WITH SPAN RATING 24/0.

PROVIDE APPROVED PLYWOOD EDGE CLIPS CENTERED BETWEEN JOISTS/TRUSSES AT UNBLOCKED ROOF SHEATHING EDGES. ALL FLOOR SHEATHING EDGES SHALL HAVE APPROVED T&G JOINTS OR SHALL BE SUPPORTED WITH SOLID BLOCKING. ALLOW 1/8" SPACING AT ALL PANEL EDGES AND ENDS OF FLOOR AND ROOF SHEATHING.

REFER TO WOOD FRAMING NOTES BELOW FOR TYPICAL NAILING REQUIREMENTS.

- ALL WOOD IN DIRECT CONTACT WITH CONCRETE OR MASONRY SHALL BE PRESSURE-TREATED WITH AN APPROVED PRESERVATIVE OR (2) LAYERS OF ASPHALT IMPREGNATED BUILDING PAPER SHALL BE PROVIDED BETWEEN UNTREATED WOOD AND CONCRETE OR MASONRY.

- PRESERVATIVE TREATED WOOD SHALL BE TREATED PER AWPA STANDARD U1 TO THE USE CATEGORY EQUAL TO OR HIGHER THAN THE INTENDED APPLICATION. TREATED WOOD FOR ABOVE GROUND USE SHALL BE TREATED TO AWPA UC3B. WOOD IN CONTINUOUS CONTACT WITH FRESH WATER OR SOIL SHALL BE TREATED TO AWPA UC4A. WOOD FOR USE IN PERMANENT FOUNDATIONS SHALL BE TREATED TO AWPA UC4B.

- FASTENERS AND TIMBER CONNECTORS USED WITH TREATED WOOD SHALL HAVE CORROSION RESISTANCE AS INDICATED IN THE FOLLOWING TABLE, UNLESS OTHERWISE NOTED.

WOOD TREATMENT	CONDITION	PROTECTION
HAS NO AMMONIA CARRIER	INTERIOR DRY	G90 GALVANIZED
CONTAINS AMMONIA CARRIER	INTERIOR DRY	G185 OR A185 HOT DIPPED OR CONTINUOUS HOT GALVANIZED PER ASTM A653 TYPE 304 OR 316 STAINLESS
CONTAINS AMMONIA CARRIER	INTERIOR WET	TYPE 304 OR 316 STAINLESS
CONTAINS AMMONIA CARRIER	EXTERIOR	TYPE 304 OR 316 STAINLESS
AZCA	ANY	TYPE 304 OR 316 STAINLESS

INTERIOR DRY CONDITIONS SHALL HAVE WOOD MOISTURE CONTENT LESS THAN 19%. WOOD MOISTURE CONTENT IN OTHER CONDITIONS (INTERIOR WET, EXTERIOR WET, AND EXTERIOR DRY) IS EXPECTED TO EXCEED 19%. CONNECTORS AND THEIR FASTENERS SHALL BE THE SAME MATERIAL. COMPLY WITH THE TREATMENT MANUFACTURERS RECOMMENDATIONS FOR PROTECTION OF METAL.

- WOOD FASTENERS


A. NAIL SIZES SPECIFIED ON DRAWINGS ARE BASED ON THE FOLLOWING SPECIFICATIONS:

SIZE	LENGTH	DIAMETER
6d	2"	0.113"
8d	2-1/2"	0.131"
10d	3"	0.148"
12d	3-1/4"	0.148"
16d BOX	3-1/2"	0.135"

- IF CONTRACTOR PROPOSES THE USE OF ALTERNATE NAILS, THEY SHALL SUBMIT NAIL SPECIFICATIONS TO THE STRUCTURAL ENGINEER (PRIOR TO CONSTRUCTION) FOR REVIEW AND APPROVAL.

NAILS - PLYWOOD (APA RATED SHEATHING) FASTENERS TO FRAMING SHALL BE DRIVEN FLUSH TO FACE OF SHEATHING WITH NO COUNTERSINKING PERMITTED. TOE-NAILS SHALL BE DRIVEN AT AN ANGLE OF 30 DEGREES WITH THE MEMBER AND STARTED 1/3 THE LENGTH OF THE NAIL FROM THE MEMBER END.


- ALL BOLTS IN WOOD MEMBERS SHALL CONFORM TO ASTM A307. PROVIDE WASHERS UNDER THE HEADS AND NUTS OF ALL BOLTS AND LAG BOLTS BEARING ON WOOD. INSTALLATION OF LAG BOLTS SHALL CONFORM TO THE NATIONAL DESIGN SPECIFICATION FOR WOOD CONSTRUCTION WITH A LEAD BORE HOLE OF 60 TO 70 PERCENT OF THE SHANK DIAMETER. LEAD HOLES ARE NOT REQUIRED FOR 3/8" AND SMALLER LAG SCREWS.



711 Saint Helens Suite #208  
 Tacoma, WA  
 253.448.7331  
 Jordan@JPJonesEngineering.com

DRAWN: JPJ

DESIGN: JPJ



**REVISIONS:**

REV NO	DESCR.	DATE
1	Permit Review	10-30-2024

**PROJECT TITLE:**

Fong Section Story Addition  
 8801 SE 56th Street  
 Mercer Island, WA

**ARCHITECT:**

Heckman Architect  
 501 Roy St, STE 232C  
 Seattle, WA 98109  
 AnHeckman@gmail.com  
 206.478.6850

**ISSUE:**

**CONSTRUCTION**

**SHEET TITLE:**

General Structural  
 Notes


SHEET SIZE: 24"x36"

SCALE: 1 1/2" = 1'-0"

DATE: 10-30-2024

SHEET NO:

**S1.1**



REVISIONS:

REV NO	DESCR.	DATE

PROJECT TITLE:

Fong Section Story Addition
   
 8801 SE 56th Street
   
 Mercer Island, WA

ARCHITECT:

Heckman Architect
   
 501 Roy St, STE 232C
   
 Seattle, WA 98109
   
 AnHeckman@gmail.com
   
 206.478.6850

ISSUE:

CONSTRUCTION

SHEET TITLE:

Foundation & Main
   
 Floor Framing Plan

SHEET SIZE: 24"x36"

SCALE: 1/4" = 1'-0"


DATE: 10-30-2024

SHEET NO:

**S2.0**

FRAMING LEGEND	
	BEARING WALL BELOW
	BEARING WALL ABOVE
	BEAM
	GREEN ROOF (LIVEROOF, STANDARD, 45psf)
	POST/STUD BELOW
	BEAM HANGER
	HOLD DOWN
	SHEARWALL

ALL SIMPSON HDU2 ARE TO BE INSTALLED AT THE BOTTOM OF THE ABOVE WOOD WALL. SEE SHEET S3.0 FOR INSTALLATION DETAILS





REVISIONS:

REV NO	DESCR.	DATE

PROJECT TITLE:

Fong Section Story Addition  
8801 SE 56th Street  
Mercer Island, WA

ARCHITECT:

Heckman Architect  
501 Roy St. STE 232C  
Seattle, WA 98109  
AnHeckman@gmail.com  
206.478.6850

ISSUE:

CONSTRUCTION

SHEET TITLE:

Upper Floor Framing Plan



SHEET SIZE: 24"x36"

SCALE: 1/4" = 1'-0"

DATE: 10-30-2024

SHEET NO:

S2.1




- ### FLOOR FRAMING NOTES:
- DO NOT DIMENSION OR SCALE STRUCTURAL PLANS. USE ARCHITECTURAL PLANS FOR ALL DIMENSIONS, DOOR, WINDOW, AND WALL PLACEMENTS.
  - WALLS AND POSTS INDICATED ARE BELOW THE FRAMING LEVEL.
  - UNDER POINT LOADS ABOVE, PROVIDE VERTICAL GRAIN STUD BLOCKING IN THE JOIST BAY AND BETWEEN TOP PLATES & HEADERS. BLOCKING TO MATCH STUDS/POSTS SIZE ABOVE.
  - TYPICAL WOOD FLOOR FRAMING CONSISTS OF ARCHITECTURAL FINISHES OVER 3/4" T&G PLYWOOD, FACE GRAIN PERPENDICULAR TO SUPPORTS OVER JOISTS PER PLAN. NAIL SHEATHING WITH 8D AT 6" O.C. EDGES AND OVER SHEAR WALLS, 12" O.C. FIELD. SEE PLANS FOR ADDITIONAL JOIST REQUIREMENTS.

### SHEARWALL SCHEDULE (1), (2), (3), (4), (5)


MARK	SHEATHING	O.S.B. EDGE NAILING	TOP PLATE CONNECTION		BASEPLATE CONNECTION	
			ROOF/JOIST BLOCKING (6),(7)	TJI	AT WOOD (8)	AT CONCRETE
SW6	7/16" O.S.B.	8d @ 6" oc	SIMPSON A35 @ 24" oc	16d @ 6" oc	16d @ 6" oc	5/8" DIA. A.B. @ 48" oc


<sup>(6)</sup>BLACK PANEL EDGES WITH 2x MIN. LAD PLAT AND NAIL PANELS TO INTERMEDIATE SUPPORTS WITH 8d @ 12" oc  
<sup>(7)</sup>8" NAILS SHALL BE 0.137" DIA. x 2.5" (COMMON) - 10" NAILS SHALL BE 0.137" DIA. x 2.5" (8d)  
<sup>(8)</sup>EMBED ANCHOR BOLTS AT LEAST 7" EMBEDMENT. ALL BOLTS SHALL HAVE 3" x 3" x 1/4" MIN. PLATE WASHERS. PLATE WASHERS SHALL EXTEND TO WITHIN 12" OF THE EDGE OF THE BOTTOM PLATE ON THE SIDE WITH SHEATHING.  
<sup>(9)</sup>ALL END STUDS SHALL RECEIVE PANEL EDGE NAILING.  
 SEE PLANS AND HOLLOW SCHEDULE FOR ALTERNATE REQUIREMENTS.  
<sup>(10)</sup>IF 6x HORIZONTAL ORIENTATION IS COMMON MAY BE SUBSTITUTED FOR A35 AT CONTRACTORS OPTION.  
<sup>(11)</sup>7x NAILER ATTACHED W/ BASE PLATE NAILING PER DETAIL. A MAY BE SUBSTITUTED FOR A35 AT CONTRACTORS OPTION.  
<sup>(12)</sup>AT MULTI-ROW NAILING, MINIMUM OFFSET BETWEEN ROWS AND ROW SPACING 12". SEE DETAIL D.



DURING THE ENGINEER'S SITE VISIT ON JUNE 6th, 2024, NO ANCHOR BOLTS WERE OBSERVED CONNECTING THE EXTERIOR WALLS TO THE CONCRETE. CONTRACTOR TO VERIFY IF NO ANCHOR BOLTS ARE FOUND, INSTALL 5/8" DIAMETER x 6" LONG GALVANIZED TITEN HD SCREW ANCHORS @ 4FT SPACING. (2) BOLTS PER SECTION OF SILL PLATE. PLACE ANCHORS WITHIN 12" OF PLATE END. PLACE ANCHOR BOLTS IN THE MIDDLE THIRD SECTION OF THE PLATE. SECURE BOLT TO SILL WITH A 3"x3"x1/4" GALVANIZED STEEL PLATE WASHER.

ALONG THIS WALL LINE, SHEATHING CAN BE PLACED ON EITHER SIDE OF WALL - BE SURE TO PLACE SHEATHING ON ENTIRE FACE OF WALL FROM SILL TO BOTTOM OF RAFTERS





REVISIONS:

REV NO	DESCR.	DATE

PROJECT TITLE:

Fong Section Story Addition  
8801 SE 56th Street  
Mercer Island, WA

ARCHITECT:

Heckman Architect  
501 Roy St. STE 232C  
Seattle, WA 98109  
AnHeckman@gmail.com  
206.478.6850

ISSUE:

CONSTRUCTION

SHEET TITLE:

Roof Framing Plan



SHEET SIZE: 24"x36"

SCALE: 1/4" = 1'-0"

DATE: 10-30-2024

SHEET NO:

**S2.2**




- ### FRAMING NOTES:
- ROOF FRAMING CONSISTS OF ROOFING (SEE ARCH DRAWINGS) OVER 5/8" CDX PLYWOOD (EXPOSURE 1 RATED), FACE GRAIN PERPENDICULAR TO SUPPORTS OVER JOISTS PER PLAN. STAGGER JOINTS. NAIL SHEATHING WITH SD AT 6" O.C. EDGES AND OVER SHEAR WALLS. 12" O.C. FIELD
  - ALL NEW EXTERIOR WALLS ARE TO BE SW6 SHEARWALLS U.N.O.
  - WALLS INDICATED ARE BELOW THE FRAMING LEVEL.
  - SEE ARCH DRAWINGS FOR ALL DIMENSIONS.


### SHEARWALL SCHEDULE (1), (2), (3), (4), (6)


MARK	SHEATHING	O.S.B. EDGE NAILING	TOP PLATE CONNECTION		BASEPLATE CONNECTION	
			ROOF/JOIST BLOCKING (6),(7)	TJI	AT WOOD (8)	AT CONCRETE
SW6	7/16" O.S.B.	8d @ 6" oc	SIMPSON A35 @ 24" oc	16d @ 6" oc	16d @ 6" oc	5/8" DIA. A.B. @ 48" oc

<sup>(6)</sup>BLACK PANEL EDGES WITH 2x MIN. LAD PLAT AND NAIL PANELS TO INTERMEDIATE SUPPORTS WITH 8d @ 12" oc  
<sup>(7)</sup>BLACK PANELS SHALL BE 0.137" DIA. x 2.5" (6mm) x 16" NAILS SHALL BE 0.137" DIA. x 2.5" (6mm)  
<sup>(8)</sup>EMBED ANCHOR BOLTS AT LEAST 7" EXPANSION BOLTS MAY BE SUBSTITUTED FOR ANCHOR BOLTS WITH 4" EMBEDMENT. TITEN HD SCREW ANCHORS MAY BE SUBSTITUTED FOR ANCHOR BOLTS W/ 4" EMBEDMENT. ALL BOLTS SHALL HAVE 3" x 3" x 1/4" MIN. PLATE WASHERS. PLATE WASHERS SHALL EXTEND TO WITHIN 12" OF THE EDGE OF THE BOTTOM PLATE ON THE SIDE WITH SHEATHING.  
ALL END STUDS SHALL RECEIVE PANEL EDGE NAILING.  
SEE PLANS AND HOLLOW'S SCHEDULE FOR ALTERNATE REQUIREMENTS.  
<sup>(9)</sup>TP6x HORIZONTAL ORIENTATION W/ 8d COMMON MAY BE SUBSTITUTED FOR A35x AT CONTRACTORS OPTION.  
<sup>(10)</sup>2x NAILER ATTACHED W/ BASE PLATE NAILING PER DETAIL A MAY BE SUBSTITUTED FOR A35x AT CONTRACTORS OPTION.  
<sup>(11)</sup>AT MULTI-ROW NAILING, MINIMUM OFFSET BETWEEN ROWS AND ROW SPACING 12". SEE DETAIL D.




ALL SIMPSON CS16 & CS14 STRAPS ARE TO BE INSTALLED AT THE BOTTOM OF THE WALL SHOWN. SEE SHEET S3.0 FOR INSTALLATION DETAILS







1 Trusses at Exterior Wall  
3/4" = 1'-0"




2 Gable Truss  
3/4" = 1'-0"




6 CS16 Between Floors  
3/4" = 1'-0"




3 Floor Trusses at Grids 1 & 2  
3/4" = 1'-0"




4 Floor Trusses at Grid B  
3/4" = 1'-0"




5 Floor Trusses at Grid A  
3/4" = 1'-0"



7 CS14 Between Floors  
3/4" = 1'-0"




8 HDU2 at Foundation  
3/4" = 1'-0"



REVIEWED FOR CODE COMPLIANCE  
December 19, 2024  
SITE COPY  
**J.P. JONES**  
ENGINEERING  
711 Saint Helens Suite #208  
Tacoma, WA  
253.448.7331  
Jordan@JPJonesEngineering.com

DRAWN: JPJ

DESIGN: JPJ



REVISIONS:

REV NO	DESCR.	DATE

PROJECT TITLE:

Fong Section Story Addition  
8801 SE 56th Street  
Mercer Island, WA

ARCHITECT:

Heckman Architect  
501 Roy St, STE 232C  
Seattle, WA 98109  
AnHeckman@gmail.com  
206.478.6850

ISSUE:

**CONSTRUCTION**

SHEET TITLE:

Foundation &  
Framing Details


SHEET SIZE: 24"x36"

SCALE: 3/4" = 1'-0"


DATE: 10-30-2024

SHEET NO:


**S3.0**




① WFCM Prescriptive Stud Cut Limits  
3/4" = 1'-0"



④ Top Plate Splice  
3/4" = 1'-0"



⑤ Typical Wall Sheathing Layout  
3/4" = 1'-0"



Typical Wall Framing Connections - Upper  
⑦ Floor  
3/4" = 1'-0"

