

Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 and 2021 Washington State Energy Code (WSEC) . This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at energycode@energy.wsu.edu or (360) 956-2042 for assistance.

This tool is for the permitting purposes only. A Manual J calculation is required to meet the requirement of the Washington State Energy Code.

Project Information

Forest Ave Lot 1
 5222 Forest Ave SE
 Mercer Island, WA 98040

Contact Information

Kati Eitzman - Sturman Architects
 9 103rd Ave NE Ste. 203
 Bellevue, WA 98004

Heating System Type:

All Other Systems

Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

Design Temperature

[Instructions](#)

Mercer Island

Design Temperature 25

Design Temperature Difference (ΔT) 45

$\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

Area of Building

Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft)

4,326

Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft)

9.5

Conditioned Volume
41,097

Glazing and Doors

[Instructions](#)

U-0.28

U-Factor X Area = UA
0.280 X 1,041 = 291.42

Skylights

[Instructions](#)

U-Factor X Area = UA
0.50 X 9 = 4.40

Insulation

Attic

[Instructions](#)

None

U-Factor X Area = UA
-- X -- = --

Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

R-38

U-Factor X Area = UA
0.026 X 2,524 = 65.62

Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 INT plus R-5 ci

U-Factor X Area = UA
0.041 X 3,178 = 130.30

Floors

[Instructions](#)

R-38

U-Factor X Area = UA
0.025 X 2,518 = 62.95

Below Grade Walls and Slabs (see Figure 1)

[Instructions](#)

Wall & Slab None

Depth Select nearest slab depth

Wall U-Factor X Area = UA
-- X -- = --

Slab F-Factor X Length = UA
-- X -- = --

Slab on Grade (see Figure 1)

[Instructions](#)

None

F-Factor X Length = UA
-- X -- = --

Location of Ducts

[Instructions](#)

Conditioned Space

Duct Leakage Coefficient
1.000

Sum of UA 554.70

Envelope Heat Load 24,961 Btu / Hour

Sum of UA x ΔT

Air Leakage Heat Load 19,973 Btu / Hour

Volume x 0.6 x ΔT x 0.018

Building Design Heat Load 44,934 Btu / Hour

Air leakage + envelope heat loss

Building and Duct Heat Load 44,934 Btu / Hour

Ducts in unconditioned space: sum of building heat loss x 1.10

Ducts in conditioned space: sum of building heat loss x 1

Maximum Heat Equipment Output 56,168 Btu / Hour

Building and duct heat loss x 1.40 for forced air furnace

Building and duct heat loss x 1.25 for heat pump

Figure 1.

