

# **DRAINAGE PUMP DESIGN**

**FOR**

**SINGLE FAMILY RESIDENCE**

**2247 66<sup>TH</sup> AVE SE**

**MERCER ISLAND, WA 98040**

November 14, 2024



*Prepared by*

**C2MY Engineers, LLC**  
P.O. Box 52883  
Bellevue, WA 98015-2883  
Contact: Choomeng Chin  
(206) 451-7856  
*cmchin.c2my@gmail.com*

*Prepared for*

**David Sheldon & Jianchu Fan**  
2247 66<sup>th</sup> Ave SE  
Mercer Island, WA 98040  
Contact: Peik Li Pang, AIA  
(425)-287-1567  
*Peikli.pang@5ft2studio.com*

This page is intentionally left blank

## TABLE OF CONTENTS

I. PROJECT OVERVIEW .....	5
A. Pump Design Requirements:.....	5
II. PUMP DESIGN DESIGN .....	7
A. Summary of Input Data:.....	7
B. Developed Peak flow Calculation:.....	7
C. Storm Duplex Pump design: .....	9
D. Pump Curve: .....	11

This page is intentionally left blank

## I. PROJECT OVERVIEW

This report provides the roof and driveway drainage pump system design calculation for the redevelopment of a single-family residence building. The site is lower than the street drainage system and site drainage runoff cannot be drained by gravity to the roadway drainage system and hence a pump is needed. The pump system will include the footing drain runoff using 2 gpm flow rate.

### A. Pump Design Requirements:

Per city requirements:

- a. The pump system shall have dual, alternating pumps with emergency on-site, back-up power supply and an external alarm system for system failure and highwater level indicator.
- b. Provide a detail section for the pump system and the structure with all dimensions and invert elevations shown.
- c. Pumped flows shall not exceed the allowable discharge rates set forth herein. Each pump shall be capable of discharging the design flow rate for the 100-year, 24-hour design storm. Provide detail calculations for the pump system including pump curve.
- d. The pump system shall discharge to an elevation higher than the downstream design water surface elevation to prevent backwater/backflow conditions. Provide such design.



**II. PUMP DESIGN DESIGN**

The calculated peak runoffs using the SBUH methodology are as follow:

Drainage area= 4,769 S.F. (0.1095 acs)

The proposed driveway design storm flow frequencies are calculated as follow:

- 2-yr/24hr – 0.0499 cfs
- 25-yr/24hr – 0.0904 cfs
- 100-yr/24hr – 0.1037 cfs

The flow rate for the footing drain is estimated to be 2 gpm and added to the peak runoff for pump calculation.

**A. SUMMARY OF INPUT DATA:**

Drainage area = 1005 SF

TIME OF CONCENTRATION CALCULATIONS

24 hr. ISOPLUVIALS:

P2=	2.00	in/day
P10=	3.00	in/day
P100=	4.00	in/day

sheet flow:	$Tt = \{(.42)(Ns*L)^{0.8}\} / \{(P2)^{0.5} * (So)^{0.4}\}$
conc. flow:	$Tt = L / (60 * Ks * (So)^{0.5})$

TIME OF CONCENTRATION CALCULATIONS

Existing	Status	Length	Ns	Ks	So%(ave)	Tt(min)	Tc Used (min.)
<b>Proposed</b>							
Impervious	Sheet Flow	46	0.011		12.5	0.37	5
Pervious	Sheet Flow						

**B. DEVELOPED PEAK FLOW CALCULATION:**

**Project Precips**

[2 yr]	2.00 in
[5 yr]	2.80 in
[10 yr]	3.00 in

[25 yr]                    3.50 in  
 [100 yr]                  4.00 in  
 [6-mo]                    1.28 in

**Dev1 Event Summary:**

BasinID	Peak Q (cfs)	Peak T (hrs)	Peak Vol (ac-ft)	Area ac	Method /Loss	Raintype	Event
-----							
Dev1	0.0499	7.83	0.0162	0.11	SBUH/SCS	TYPE1A	2 yr
Dev1	0.0770	7.83	0.0252	0.11	SBUH/SCS	TYPE1A	10 yr
Dev1	0.0904	7.83	0.0298	0.11	SBUH/SCS	TYPE1A	25 yr
Dev1	0.1037	7.83	0.0343	0.11	SBUH/SCS	TYPE1A	100 yr

**Drainage Area: Dev1**

Hyd Method:	SBUH Hyd	Loss Method:	SCS CN Number
Peak Factor:	484.00	SCS Abs:	0.20
Storm Dur:	24.00 hrs	Intv:	10.00 min
	Area	CN	TC
Pervious	0.0000 ac	86.00	0.00 hrs
Impervious	0.1094 ac	98.00	0.01 hrs
Total	0.1094 ac		

**Supporting Data:**

**Impervious CN Data:**

Driveway, open parking & access	98.00	0.0276 ac
Roof	98.00	0.0819 ac

**Impervious TC Data:**

Flow type:	Description:	Length:	Slope:	Coeff:	Travel Time
Sheet	Overland	46.00 ft	12.50%	0.0110	0.40 min

**C. STORM DUPLEX PUMP DESIGN:**

**2427 66th Ave SE SE, Mercer Is, WA - STORM PUMP CAPACITY ANALYSIS**

11/11/2024

STORM WATER LIFT STATION DESIGN

A. DETERMINE THE REQUIRED RATE OF PUMPING;

100-YR PEAK FLOW, Qmax = 0.1037 cfs = 49 GPM (From SBUH)  
(Including 2gpm for ftg. Drain)

B. COMPUTE THE STORAGE REQUIREMENT FOR THE WETWELL:

USING 2 PUMPS AND 1 CYCLE PER HOUR  
TIME FOR ONE PUMP CYCLE:

$$T=(V/Q-S)+(V/S)$$

Where:

T = THE TIME FOR ONE PUMP CYCLE IN MINUTES = 24  
 V = THE EFFECTIVE VOLUME OF THE WETWELL IN GALLON = V  
 Q = THE PUMPING RATE IN GALLONS PER MINUTE = 49  
 S = THE FLOW INTO THE WETWELL IN GALLONS PER MINUTE = 22 0.0499 cfs  
 (Using 2-yr Peak)

$$V = TS(Q-S)/Q = 290$$

USE 4 FEET DIAMETER WET WELL  
 VOLUME PER FOOT = 94.00 GAL/FT  
 WORKING DEPTH = 3.08 FEET

C. DETERMINE THE FORCEMAIN DIAMETER:

Qmax = 49 GPM = 0.11 CFS

MAXIMUM CROSS SECTION REQUIRED = 0.04 SF  
 (FOR VEL. = 3 FPS) = 5.19 SI

USE 2 INCH DIAMETER HDPE PIPE, V= Q/A  
 (AREA = 0.02 (SF) = 4.96 FPS <10 FPS OK  
 FOR 3 INCH DIAMETER HDPE PIPE, V= Q/A  
 0.05 (SF) = 2.20 FPS << 3FPS NG

## D. DETERMINE HEAD LOSS OF HDPE FORCE MAIN:

$$H = (Q / (0.006757)(C)(D^{2.63}))^{1.85}$$

WHERE: H = THE HEAD LOSS IN FEET PER 1000 FEET OF PIPE = H  
 Q = THE FLOW IN GALLON PER MINUTE = 49  
 C = THE HAZEN-WILLIAM COEFFICIENT OF ROUGHNESS = 140  
 D = THE PIPE DIAMETER IN INCHES = 2 USED

H = 50.03 FEET

LENGTH OF PIPE = 111 FEET HEAD LOSS IN PIPE = 6 FT.

## E. COMPUTE THE TOTAL DYNAMIC HEAD (TDH)

a) STATIC DISCHARGE HEAD = 18.62 FEET  
 DISCHARGE ELEVATION = 161.62  
 PUMP OFF ELEVATION = 143

b) MINOR LOSSES = 5.9  
 2 - 90 DEG. ELL = 1.4  
 1 - GATE VALVE = 0.2  
 1 - CHECK VALVE = 2.5  
 1 - TEE = 1.8

c) TOTAL DISCHARGE HEAD LOSS = 30.07 FEET

## G. COMPUTE THE REQUIRED BRAKE HORSEPOWER:

$H_{\text{brake}} = (GPM \times TDH) / (3960 \times \text{EFF.}) = 0.61$  (Required Pump) USING SUBMERSIVE PUMP WITH  
 EFF. OF 60 %  
 (Use 3/4 HP pump)

WHERE: GPM = FLOW RATE IN GALLON PER MINUTE  
 TDH = TOTAL DYNAMIC HEAD OF THE SYSTEM IN FEET  
 WHEN DELIVERING THE REQUIRED FLOW RATE  
 3930 = A CONSTANT  
 EFF = PUMP EFFICIENCY EXPRESSED IN DECIMAL FORM

**D. PUMP CURVE:**

Use Goulds Pump WS\_BHF Series, Model WE0718H (3/4 HP) or Equal.  
See Plan for pump details.

