

**STORMWATER DRAINAGE REPORT ADDENDUM**

*for*  
**WISHWAS SFR REMODEL**  
**8203 Avalon Drive**  
**Mercer Island, WA**

**MERCER ISLAND #: 2505-004**

*ISSUE DATE: 10/08/25*

*REVISION DATE:*

*PREPARED & REVIEWED BY:*  
**TIMOTHY A. SARKELA, P.E.**



**10/08/25**

**CLIENT**

ATTN: Jen Tamblin, Architect  
Madhuri Koushik & Wishwas Kumar  
Gummanur Mohan, Trustees  
2441 66<sup>th</sup> Ave SE  
Mercer Island, WA 98040

**ENGINEER**

WESI Land Use Consultants  
Job # 24-1102-A

**Addendum to Minimum Requirement #5**

I viewed TV footage of the roof drain line coming off the northeast corner of the existing house and down to the street. The drainage line appears to be functioning and has been rated by Action Jackson Plumbing as in ‘overall fair condition’ and ‘with minor debris... but flowing properly.’ As this is the case, and I am unaware of any reported drainage issues for this line, I can vouch for reusing this line for the house remodel project.

The remodeled roof, having a similar area and runoff capacity, may utilized the concrete roof drain line from the house down to the street. To do so, the new or existing reused downspouts will connect into the roof drain where roof drain connections currently exist.