



1000 Cedar Avenue • Marysville, WA 98270

425-356-2700 INFO@WESI.CO

January 12, 2026

City of Mercer Island  
9611 SE 36<sup>th</sup> Street, Mercer Island, WA 98040

The following is a list of changes to the plans since last submittal.

Site Plan

1. A new water meter is now shown south of the existing one.
2. Text added to stormwater addendum.
3. Pipe inspection logs.
  - a. The site plan is updated with inspection locations dimensioned.
  - b. A more clear description of the pipe inspection has been added to a stormwater addendum, now included in this submittal.
  - c. The addendum states the pipe can be reused as-is.

Let me or the permittee know if you have any questions or concerns regarding this set of responses or the attached documents.

Sincerely,

*Timothy Sarkela*  
Project Engineer