

DRAINAGE REPORT COMMENTS		
	City Comment	Response
	There's no permit on file for the drainage pipe you mentioned. The city doesn't have any as-built records or inspection history for this system. Please update the report accordingly.	JCE Response: The report has been updated to accurately reflect the storm system.
	MICC 15.09 includes additional requirements for MR#5—please make sure to address those in the report as well.	JCE Response: The report has been updated to include the additional requirements for MR#5 in MICC 15.09.
	Figure 5 shows 1.37 ac, not 1.42 ac.	JCE Response: The table has been updated to reflect the same area as Figure 5.
	Can you specify which figure corresponds to this number?	JCE Response: The 24,626 square feet is from Figure 5 and corresponds to the parking lot area of 0.57 acres (24,626 square feet).
	This information doesn't appear to be included in Appendix B, and I also couldn't find the design details for the Filterra system. Please confirm and update if available.	JCE Response: The water quality design flow from MGS Flood is already included in Appendix B. The design drawings for storm repair work has been included in Appendix C for reference for the design details of the Filterra system.
	Can you specify which figure corresponds to this number?	JCE Response: This number corresponds to Figure 5 of the report.
	Can you specify which figure corresponds to this number?	JCE Response: This number corresponds to Figure 8 of the report.
	Can you provide an exhibit associated with the drainage pipes, showing their layout and relevant details?	JCE Response: The storm repair plans have been provided in Appendix C for reference for the associated drainage pipes, their layout, and relevant details.
	Can you specify which figure corresponds to this number?	JCE Response: This number corresponds to Figure 9 – Water Quality Design Flow Areas.
	Can you include a summary of the impervious and previous surface	JCE Response: A summary table has been added to Figure 5 to

	areas on the exhibit to match what's shown in Table 2? That way everything stays consistent.	match what is shown in Table 2 to ensure consistency.
	Can you show the square footages for pavement, roof, and landscaping areas within each sub-basin, so they correspond with the calculation tables?	JCE Response: We are not able to clearly annotate the exhibit, hence the detailed summary table provided.