



STRUCTURAL PERMIT CORRECTIONS

October 6, 2025

Collaborative Co.
Craig Pontius
3800 Woodland Park Ave N #300
Seattle, WA 98103

RE Permit corrections for 6427 E Mercer Way, Mercer Island, WA 98040

We have received and reviewed the structural comments regarding the 6427 E Mercer Way project, project number CAO25-014. Below are the corresponding responses to the structural comments for the correction notice prepared by Grace Manahan dated July 23, 2025:

9. Calculations for the site retaining wall have been updated for the 50pcf loading for sloped conditions behind the wall. Please see revised calculations provided. Retaining wall schedule on 6/S3.0 has been updated to match the required size and reinforcing per the calculations. Note 10 on S1.0 has been updated to indicate the design value for the active pressure due to sloped conditions as well.

We trust that this addresses all the structural concerns. Please give us a call if you have any further questions.

Sincerely,

**MALSAM TSANG STRUCTURAL
ENGINEERING CORPORATION**

A handwritten signature in blue ink that reads "Jessica Fortin".

Jessica Fortin
Project Engineer