



October 28, 2025

City of Mercer Island
9611 Southeast 36th Street
Mercer Island, Washington 98040

**RE: Plan Review
7619 Southeast 22nd Street
Mercer Island, Washington
RGI Project No. 2020-404-3**

References: Architectural Innovations, Plan Sheets Cover through D1 dated October 23, 2025
Mulhern + Kulp, Plan Sheets S0.0 through SD-3 dated November 20, 2024
The Riley Group, Inc., Geotechnical Engineering Report dated September 15, 2020
and updated May 4, 2022, Geotechnical Engineering Report Addendum dated May
4, 2022, and Geotechnical Report addendum dated September 26, 2022

Dear Reviewer,

As requested, The Riley Group, Inc. (RGI) is providing this letter reviewing the plans for the above referenced project. The project includes constructing a single-family residence (SFR) on Lot 2 of the short plat. RGI previously prepared the referenced reports and addendums for the proposed construction of the short plat and homes. RGI was onsite during the installation of the utilities for the project.

RGI has reviewed the referenced plans, and the plans substantially comply with the recommendations of our referenced reports.

Respectfully submitted,

THE RILEY GROUP, INC.



10/28/2025

Collin McCracken, PE
Senior Geotechnical Engineer

Corporate Office: 17522 Bothell Way Northeast, Bothell, WA 98011
Tacoma Office: 708 Broadway Suite #100B Tacoma, WA 98402
Phone 425.415.0551 • **Fax** 425.415.0311

www.riley-group.com