

Lund Correction Letter V4

A new ADU application is still needed. The ADU permit will need to be approved prior to the building permit.

ADU application and title report included with this submittal.

Per arborist report provided:

- Label limits of disturbance consistent with table of trees they had provided.
- Show tree protection fencing on the plan along those limits. Refer to tree protection specifications page for further tree protection specifications.
- Show on plans that 4-inch layer of coarse arborist woodchips throughout the tree protection area will be placed. Keep woodchips 1 foot from the trunk of the tree.
- Add tree protection diagram to plans:

https://www.mercerisland.gov/sites/default/files/fileattachments/community_planning_amp_devlopment/page/2091/tree_protection_area_signage_chain_link_update.pdf

Required items added to site plan.

Provide required tree inventory worksheet

https://www.mercerisland.gov/sites/default/files/fileattachments/community_planning_amp_devlopment/page/21988/mercerislandtreeinventory.pdf

Tree inventory worksheet included with this submittal.