From: Alison Van Gorp alison.vangorp@mercergov.org

Subject: FW: Stop Work Order until plan discrepancy resolved, Permit No. 2004-045, Gartz Driveway Repair, 7703 West Mercer Way

Date: June 26, 2020 at 3:59 PM

To: shane miller shane_miller_usa@yahoo.com

FYI. I will forward a photo of the actual stop work order once it's posted. I believe the code compliance officer is in route now.

From: Don Cole < Don.Cole@mercergov.org >

Sent: Friday, June 26, 2020 3:46 PM

To: William Gartz < william.gartz@gmail.com >

Cc: David Henderson < david.henderson@mercergov.org >; Alison Van Gorp

<alison.vangorp@mercergov.org>

Subject: Stop Work Order until plan discrepancy resolved, Permit No. 2004-045, Gartz Driveway

Repair, 7703 West Mercer Way

Hello Mr. Gartz,

I called to discuss this matter before posting a stop work order and left a couple voicemails. I am sorry that I was not able to reach you. An inspector will be posting a stop work order this afternoon because the submitted plans contain inaccurate information. Specifically, the existing verse proposed grades contain error(s) resulting in different elevation changes (see the Table), which must be resolved prior to work as it could result in significantly steepened grades in some sections of the driveway.

Please submit revised plans to correct the discrepancy. The stop work order remains until the revised plans can be reviewed for code conformance and approved.

Please let me know if you have any questions or concerns.

Don Cole

Building Official
City of Mercer Island - Community Planning & Development
206.275.7701 | mercergov.org/CPD | mybuildingpermit.com

Due to the COVID-19 outbreak, Community Planning and Development has modified our operations. <u>City Hall and the Permit Center are closed to the public</u>. There is no "walk in" permit service; staff are working remotely and services are being continued via remote operations. More information is available on the City's website: <u>www.mercergov.org/cpd</u>. Please contact us by phone for general customer support at 206-275-7626.

Notice: Emails and attachments may be subject to disclosure pursuant to the Public Records Act (chapter 42.56 RCW)