

RETURN ADDRESS

To Whom It May Concern:

DATE: 12-23-24

The unused underground residential heating oil tank(s) or UURHOT at:

7414 78th ave S.E., Mercer Is


Has been removed to the International Fire Code 5704.2.14.1,2 specifications adopted by the local Fire Marshal.

Mercer Island Fire Permit #2412-047

The tank has been pumped out and triple rinsed and washed to remove as much residual product and bottom sludge to insure the E.P.A. and D.O.E. standards of tank cleaning and before disposal.

Tank Location was from the Southwest Property Corner to the center of tank pit is approx

28 feet North, 32 East



Tank Wise
5405 W MARGINAL WAY SW
SEATTLE, WA 98106
Contractor lic# TANKWL*008DG
I.C.B.O. 1017159-U2
PH # (206) 937-3995

TANK WISE REPRESENTATIVE

PROPERTY OWNER



City of Mercer Island
Development Services
 9611 SE 36th Street
 Mercer Island, WA 98040
 Inspection Request Line (206)236-3587
 General Information (206)236-5300
 www.ci.mercer-island.wa.us

FUEL TANK PERMIT

REMOVAL

Permit No. 2412-047
Main Permit No.
Project No.

Site Address: 7414 78TH AVE SE	Valuation: 0.00	Parcel No. 2524049075
Owner: SAINTFIELD2 LLC Tenant: Mailing Address: PO BOX 792 MERCER ISLAND WA 98040 Phone: (425)473-0578	Description of Work: REMOVE 300 GAL UST	

Legal Description

Lot:	Block:	Plat:
Contractor: TANK WISE LLC Address: 5405 W MARGINAL WAY SW SEATTLE WA 98106		Phone: (206)937-3995 State Contractor Lic #: TANKWL*008DG MI Business Lic#: 960058

Type of Const.: FUEL TANK	Occ Load:	No. Stories: 0.00	Map Loc.:
Decommission:	Installation:	Removal:	IFCI Certificate #:

Associated Permits:

FEES	Receipt# & Date	Comments
HOME FUEL TANK	200.00 256231 12/20/2024	(12/6/2024 11:45 AM DJJ) Pump out and triple rinse 300 gallon residential heating oil tank to prepare for removal. Take away tank for cleaning and disposal.
TOTAL FEE	\$200.00	
TOTAL FEES PAID	\$200.00	
TOTAL FEES DUE	\$0.00	

WAC 173-340 State Model Toxics Control Act requires the owner or operator must contact the State Department of Ecology (425) 649-7000 within 90 days of contamination discovery.

Contractor shall provide site drawing. The work is to be completed per the Uniform Fire Code Article 79 and NFPA 31. A site drawing with scale is to be submitted to the Fire Marshal for approval.
 Permit expire if work is not commenced within 180 days or ceases more than 180 days. The City of Mercer Island is not responsible for reviewing the applicability of private covenants to this permit. Compliance with private plat covenants is the sole responsibility of the applicant/owner.

Wendi Wia

 Signature of Owner/Contractor/Authorized Agent 12/23/24
 Date

Project No.
Main Permit No.
Permit No. 2412-047

FILE COPY