


Structural Analysis Report

Site Name: Mercer Island
Site Number: SD05
Project: LTE 1C RRH Swap
Client: AT&T
FA #: 10092489
IWM #: WSWOR0048444
PTN #: 3801A1HCV6
Structure Type: Rooftop
Structure Description: Slab
Site Location: 7900 SE 28th Street
Mercer Island, WA 98040
King County
47.58564°N, 122.23206°W

Analysis Load Case: Final Configuration
Analysis Result: **Adequate @ 64%**

See Conclusion & Recommendations for
installation requirements.

SEAL



Michael Leeper, PE
Director of Engineering

Rev: 0

May 29, 2025

REVIEWED

By mpaulinio at 7:41 am, Jun 06, 2025

1.0 Introduction

At the request of AT&T , an analysis of the existing structure has been performed. All supporting documents have been obtained from the client and are assumed to be accurate and applicable to this site. The structure was analyzed using Enercalc.

2.0 Analysis Procedure & Design Criteria

The following documents were provided for site Mercer Island :

The structures have been analyzed pursuant to the following Design Criteria:

| Adopted Codes: | |
|--|---|
| IBC: 2021 | Local Codes: 2021 MICC |
| TIA: 222-H | AISC: 16TH ED. |
| ASCE: 7-16 | ACI: 318-19 |
| Gravity Design Loading: | |
| Assumed Minimum Design Roof Loading: D _L : 15 psf; R _{LL} : 20 psf; S _L : 25 psf | |
| Wind Design Loading: | |
| Design Wind = 98 mph [3-sec gust Ultimate] | |
| Design Wind W/ ICE = 30 mph [3-sec gust Ultimate] with 1" ice | |
| Exposure Category C | Topographic Category 1 K _{zt} =1.0 |
| Risk Category II | Ground Elevation = 93' (NAVD 88) |
| -- | Live Load(s) reduction is confirmed to either not govern or not be applicable to mounts |
| Seismic Design Loading: | |
| Site Class D-Default S _s = 1.394g, S ₁ = 0.485g, S _{DS} = 1.115g | Importance Factor, I _p = 1.0 |

3.0 Proposed Appurtenance & Equipment Information

Table 3.1 – Proposed AT&T Final Antenna Configuration¹

| RAD Height (ft) | Qty. | Appurtenance ^{1,2} | Sector | Coax | Mount type | Carrier |
|-----------------|----------|-------------------------------|--------------------------|---|---------------|---------|
| 67'-6" | 3 | AIR6472 B77G B77M | Alpha/ Beta/ Gamma | (3) Fiber (6) 6 AWG DC Power | Pipe Mount | AT&T |
| 66'-0" | 3 | CMA-UBTMLBMLBHH-6516-16-21-21 | | | | |
| | 3 | NNH4-65B-R6 | | | | |
| | 3 | 4490 B5/B12A | | | | |
| | 3 | 4494 B14/B29 | | | | |
| | 3 | 4890 B25/B66 | | | | |
| | 3 | DC9-48-60-24-PC16-EV | | | | |

1. Bold items denote appurtenances to be installed
2. Refer to A&E Construction Drawings for additional information regarding final antenna and equipment locations and orientations.

4.0 Structural Analysis Results and Conclusion

Upon reviewing the results of this analysis, it is our opinion that the existing structure meets the specified code requirements. **The structure is considered acceptable to support the final loading configuration** as listed within this report. The controlling structure usages are displayed in the tables below:

Table 4.1 – Rooftop Structure Capacity

| Load Case | Governing Assembly Components | Capacity | Results |
|------------|-------------------------------|----------|---------|
| Worst Case | Slab | 64% | Pass |

The additional equipment proposed for the referenced project will not increase the design gravity loading by more than 5 percent or the lateral loading by more than 10 percent, therefore the proposed installation is acceptable per the requirements listed in sections 502.4 and 502.5 of the 2021 IEBC. See appendix for details.

Table 4.2 – Structural Component Material Strengths

| Structural Component | Nominal Strength/Material ¹ |
|--|---|
| Pipe | $F_y = 35$ ksi (A53, Gr. B) |
| Tube | $F_y = 46$ ksi (A500, Gr. B) |
| Structural Shapes (L, C, W, etc.), Plate & Bar | $F_y = 36$ ksi (A36) |
| Wood | Dimension Lumber: DF-L No. 2 GluLam: DF/DF 24F-V4 |
| Uni-Strut (P1000, etc.) | $F_y = 33$ ksi (A570, Gr. 33) |
| Connection Bolts | A325 |
| U-Bolts / Threaded Rod | SAE J429 Grade 2 (Substitution: ASTM A449) $F_y = 57$ ksi (Yield) & $F_u = 74$ ksi (Tension) |
| | SAE J429 Grade 5 (¼" to 1" Nominal ϕ) $F_y = 92$ ksi (Yield) & $F_u = 120$ ksi (Tension) |
| Mechanical Anchors | Concrete: HILTI KWIK Bolt T22 Stainless Steel Expansion Anchors (ICC-ES ESR-4266) |
| | CMU: Threaded Rod / Rebar HILTI HIT-HY 270 Epoxy (ICC-ES-ESR-4143) |
| Stainless Steel Bolts | 18-8 Stainless, Grade 316/304 $F_y = 74$ ksi (Yield) & $F_u = 29$ ksi (Tension) |
| Welds | E70XX Electrodes |
| Platform Steel Grating | McNichols GW Series – 1-1/2"x1/8" (8.3 psf) (Or Equivalent) |
| Fiberglass Reinforced Plastic (FRP) | $F_u = 33,000$ psi $E = 2,600,000$ psi |
| Concrete / Reinforcing | $f'_c = 3,000$ psi / $F_y = 60$ ksi |
| Concrete Slab Post-Tensioning | $F_y = 270$ ksi Ultimate Strength |
| CMU | $f'_m = 1,500$ psi |

1. Strengths listed were assumed for this analysis and are based upon ASTM, AISC, RCSC, AWS and ACI preferred specification values. Values and materials are consistent with industry standards. Material strengths were taken from original design documents when available.

4.3 Analysis Notes & Assumptions

Core One Consulting USA does not take responsibility for the appurtenances or equipment loading of other carriers, as these fall outside the scope of this analysis. This evaluation focuses solely on the areas and structural members immediately adjacent to the referenced carriers existing and proposed equipment and antenna mount assemblies. Our assessment is based only on the information provided, and we have not independently verified the existing structural conditions. If any of the reported conditions (such as appurtenance loading, member sizes, etc.) are inaccurate, please contact our office immediately to request an amended report, as any discrepancies will render this evaluation inaccurate. This analysis confirms the adequacy of the primary components of the structure. However, it's important to note that not all connections, welds, bolts, plates, etc., were individually detailed and analyzed. In instances where specific analysis was not conducted, it was assumed that the existing connection plates, welds, bolts, etc., were sufficient to develop the full capacity of the main structural members.

Furthermore, this analysis does not account for unusual or extreme wind events, rime/in-cloud ice loadings, harmonic or nodal vibration, vortex shedding, or similar conditions. Therefore, it is the owner's responsibility to determine the appropriate design wind speed and the amount of ice accumulation beyond code minimum values that should be considered in the analysis.

This report solely evaluates the proposed carrier's structure outline in the appendix. It does not assess the adequacy of other mounts, tower, building or coaxial mounting attachments, which are assumed to be adequate and installed per manufacturer requirements for the purposes of this analysis.

| PROJECT DATA | |
|--------------------|---------------|
| Project Number: | SD05 |
| Carrier: | AT&T Mobility |
| Carrier Site ID: | 10092489 |
| Carrier Site Name: | Mercer Island |
| Date: | 4/25/2025 |


| CODES AND STANDARDS | |
|---------------------|-----------|
| Building Code: | 2021 IBC |
| Local Code: | 2021 MICC |
| Analysis Code: | TIA-222-H |
| Design Criteria | LRFD |

| STRUCTURE DETAILS | | |
|--------------------|----------|----|
| Structure Type: | Building | |
| Structure Height: | 62.8 | ft |
| Mount Status: | Existing | |
| Mount Type: | Pipe | |
| Mount Elevation: | 66.0 | ft |
| Number of Sectors: | 3 | |

| SITE PARAMETERS | | | | |
|--------------------------------|-------------|------------------|---------------------------|-------|
| Classification | | | Topography | |
| Risk Category: | II | | Category: | 1 |
| Exposure Category: | C | | Feature: | 0 |
| Site Class: | D - Default | | Calculated Factor: | 1.000 |
| Wind and Ice Parameters | | | Seismic Parameters | |
| Design Wind Speed: | 98 | | Short Period Accel.: | 1.394 |
| Ice Wind Speed: | 30 | 1-Second Accel.: | 0.485 | |
| Design Ice Thickness: | 1.00 | | | |

| CALCULATIONS | | | | |
|------------------------|--------|--|----------------------|---------|
| Wind and Ice | | | Seismic | |
| Velocity Pressure: | 26.99 | | Short Period Design: | 1.11520 |
| Ice Velocity Pressure: | 2.34 | | 1-Second Design: | 0.38800 |
| Ice Thickness: | 1.0718 | | Short Period Coef.: | 1.20000 |
| | | | 1-Second Coef.: | 1.20000 |

| EQUIPMENT SUMMARY | | | | | | | | | | | |
|-----------------------------|------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Equipment Model | CFD Antenna Increments | | | | | | | | | | |
| -- | 0 | 10 | 20 | 30 | 40 | 45 | 50 | 60 | 70 | 80 | 90 |
| ERICSSON AIR 6472 B77G/B77M | 4.9 | 4.8 | 4.4 | 3.9 | 3.3 | 3.1 | 2.9 | 2.4 | 1.9 | 1.6 | 1.7 |
| COMMSCOPE NNH4-65B-R6 | 6.9 | 8.5 | 9.0 | 8.5 | 7.8 | 7.4 | 6.9 | 5.2 | 4.3 | 3.1 | 2.4 |



Core One Consulting USA
MZ
SD05

Mercer Island

SK-1
Apr 25, 2025 at 11:41 AM
SD05_loaded.r3d

Concrete Beam

Project File: SD05.ec6

LIC# : KW-06015182, Build:20.24.08.01

(c) ENERCALC INC 1983-2023

DESCRIPTION: Slab at Mount Location

CODE REFERENCES



Calculations per ACI 318-19, IBC 2021, ASCE 7-16

Load Combination Set : ASCE 7-16

General Information

| | | | | | |
|-------------------------------|---|--------------|--------------------------------------|-----------|--------------|
| f'_c | = | 4.0 ksi | ϕ Phi Values | Flexure : | 0.90 |
| $f_r = f'_c^{1/2} \cdot 7.50$ | = | 474.342 psi | | Shear : | 0.750 |
| ψ Density | = | 145.0 pcf | β_1 | = | 0.850 |
| λ LtWt Factor | = | 1.0 | Fy - Stirrups | = | 40.0 ksi |
| Elastic Modulus | = | 3,122.0 ksi | E - Stirrups | = | 29,000.0 ksi |
| f_y - Main Rebar | = | 60.0 ksi | Stirrup Bar Size # | = | 3 |
| E - Main Rebar | = | 29,000.0 ksi | Number of Resisting Legs Per Stirrup | = | 2 |

Seismic Design Category = A



Cross Section & Reinforcing Details

Rectangular Section, Width = 100.0 in, Height = 9.0 in

Span #1 Reinforcing....

10-#5 at 1.0 in from Bottom, from 0.0 to 7.802 ft in this span

Load for Span Number 1

Uniform Load : D = -0.0150, Lr = -0.020, S = 0.0250 ksf, Tributary Width = 8.333 ft, (Design Loads)

Point Load : D = -0.470, W = -0.9150 k @ 4.802 ft, (Mount)

Point Load : D = -1.917 k @ 7.802 ft, (Brick Cladding)

Uniform Load : D = -0.9063 k/ft, Tributary Width = 1.0 ft, (Beam Weight)

DESIGN SUMMARY

Design OK

| | |
|--------------------------------|------------------------|
| Maximum Bending Stress Ratio = | 0.637 : 1 |
| Section used for this span | Typical Section |
| Mu : Applied | 68.633 k-ft |
| Mn * Phi : Allowable | 107.784 k-ft |
| Location of maximum on span | 0.000 ft |
| Span # where maximum occurs | Span # 1 |

Maximum Deflection

| | | | | |
|-----------------------------------|-----------|---------|----------------|-----------------------------|
| Max Downward Transient Deflection | 0.000 in | Ratio = | 0 < 360.0 | Lr Only |
| Max Upward Transient Deflection | -0.007 in | Ratio = | 26624 >= 360.0 | |
| Max Downward Total Deflection | 0.000 in | Ratio = | 0 < 180.0 | |
| Max Upward Total Deflection | -0.149 in | Ratio = | 1256 >= 180.0 | Span: 1 : +D+0.750Lr+0.450W |

Maximum Forces & Stresses for Load Combinations

| Load Combination | Segment | Span # | Location (ft) along Beam | Bending Stress Results (k-ft) | | |
|--------------------------|----------|--------|-----------------------------|---------------------------------|---------|--------------|
| | | | | Mu : Max | Phi*Mnx | Stress Ratio |
| MAXIMUM BENDING Envelope | Span # 1 | 1 | 7.802 | 68.63 | 107.78 | 0.64 |

Concrete Beam

Project File: SD05.ec6

LIC# : KW-06015182, Build:20.24.08.01

(c) ENERCALC INC 1983-2023

DESCRIPTION: Slab at Mount Location



| Load Combination Segment | Span # | Location (ft) along Beam | Bending Stress Results (k-ft) | | |
|-----------------------------|--------|-----------------------------|---------------------------------|---------|--------------|
| | | | Mu : Max | Phi*Mnx | Stress Ratio |
| +1.40D | | | | | |
| Span # 1 | 1 | 7.802 | 68.04 | 107.78 | 0.63 |
| +1.20D+0.50Lr | | | | | |
| Span # 1 | 1 | 7.802 | 60.86 | 107.78 | 0.56 |
| +1.20D+0.50S | | | | | |
| Span # 1 | 1 | 7.802 | 55.15 | 107.78 | 0.51 |
| +1.20D+1.60Lr | | | | | |
| Span # 1 | 1 | 7.802 | 66.44 | 107.78 | 0.62 |
| +1.20D+1.60Lr+0.50W | | | | | |
| Span # 1 | 1 | 7.802 | 68.63 | 107.78 | 0.64 |
| +1.20D+1.60Lr-0.50W | | | | | |
| Span # 1 | 1 | 7.802 | 64.24 | 107.78 | 0.60 |
| +1.20D+1.60S | | | | | |
| Span # 1 | 1 | 7.802 | 48.18 | 107.78 | 0.45 |
| +1.20D+1.60S+0.50W | | | | | |
| Span # 1 | 1 | 7.802 | 50.37 | 107.78 | 0.47 |
| +1.20D+1.60S-0.50W | | | | | |
| Span # 1 | 1 | 7.802 | 45.98 | 107.78 | 0.43 |
| +1.20D+0.50Lr+W | | | | | |
| Span # 1 | 1 | 7.802 | 65.25 | 107.78 | 0.61 |
| +1.20D+0.50Lr-W | | | | | |
| Span # 1 | 1 | 7.802 | 56.46 | 107.78 | 0.52 |
| +1.20D+0.50S+W | | | | | |
| Span # 1 | 1 | 7.802 | 59.54 | 107.78 | 0.55 |
| +1.20D+0.50S-W | | | | | |
| Span # 1 | 1 | 7.802 | 50.76 | 107.78 | 0.47 |
| +0.90D+W | | | | | |
| Span # 1 | 1 | 7.802 | 48.13 | 107.78 | 0.45 |
| +0.90D-W | | | | | |
| Span # 1 | 1 | 7.802 | 39.35 | 107.78 | 0.37 |
| +1.20D+0.20S | | | | | |
| Span # 1 | 1 | 7.802 | 57.05 | 107.78 | 0.53 |
| +0.90D | | | | | |
| Span # 1 | 1 | 7.802 | 43.74 | 107.78 | 0.41 |

ASCE Hazards Report

Address:
7900 SE 28th St
Mercer Island, Washington
98040

Standard: ASCE/SEI 7-16
Risk Category: II
Soil Class: D - Default (see Section 11.4.3)

Latitude: 47.585757
Longitude: -122.232083
Elevation: 93.02845448937765 ft (NAVD 88)



Wind

Results:

| | |
|--------------|---------|
| Wind Speed | 98 Vmph |
| 10-year MRI | 67 Vmph |
| 25-year MRI | 74 Vmph |
| 50-year MRI | 78 Vmph |
| 100-year MRI | 83 Vmph |

Data Source: ASCE/SEI 7-16, Fig. 26.5-1B and Figs. CC.2-1–CC.2-4, and Section 26.5.2

Date Accessed: Mon Apr 07 2025

Value provided is 3-second gust wind speeds at 33 ft above ground for Exposure C Category, based on linear interpolation between contours. Wind speeds are interpolated in accordance with the 7-16 Standard. Wind speeds correspond to approximately a 7% probability of exceedance in 50 years (annual exceedance probability = 0.00143, MRI = 700 years).

Site is not in a hurricane-prone region as defined in ASCE/SEI 7-16 Section 26.2.

Site Soil Class: D - Default (see Section 11.4.3)

Results:

| | | | |
|------------|-------|--------------------|-------|
| S_s : | 1.394 | S_{D1} : | N/A |
| S_1 : | 0.485 | T_L : | 6 |
| F_a : | 1.2 | PGA : | 0.596 |
| F_v : | N/A | PGA _M : | 0.715 |
| S_{MS} : | 1.672 | F_{PGA} : | 1.2 |
| S_{M1} : | N/A | I_e : | 1 |
| S_{DS} : | 1.115 | C_v : | 1.379 |

Ground motion hazard analysis may be required. See ASCE/SEI 7-16 Section 11.4.8.

Data Accessed: Mon Apr 07 2025

Date Source: [USGS Seismic Design Maps](#)

Ice

Results:

Ice Thickness: 1.00 in.
Concurrent Temperature: 25 F
Gust Speed 30 mph

Data Source: Standard ASCE/SEI 7-16, Figs. 10-2 through 10-8

Date Accessed: Mon Apr 07 2025

Ice thicknesses on structures in exposed locations at elevations higher than the surrounding terrain and in valleys and gorges may exceed the mapped values.

Values provided are equivalent radial ice thicknesses due to freezing rain with concurrent 3-second gust speeds, for a 500-year mean recurrence interval, and temperatures concurrent with ice thicknesses due to freezing rain. Thicknesses for ice accretions caused by other sources shall be obtained from local meteorological studies. Ice thicknesses in exposed locations at elevations higher than the surrounding terrain and in valleys and gorges may exceed the mapped values.

The ASCE Hazard Tool is provided for your convenience, for informational purposes only, and is provided “as is” and without warranties of any kind. The location data included herein has been obtained from information developed, produced, and maintained by third party providers; or has been extrapolated from maps incorporated in the ASCE standard. While ASCE has made every effort to use data obtained from reliable sources or methodologies, ASCE does not make any representations or warranties as to the accuracy, completeness, reliability, currency, or quality of any data provided herein. Any third-party links provided by this Tool should not be construed as an endorsement, affiliation, relationship, or sponsorship of such third-party content by or from ASCE.

ASCE does not intend, nor should anyone interpret, the results provided by this Tool to replace the sound judgment of a competent professional, having knowledge and experience in the appropriate field(s) of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the contents of this Tool or the ASCE standard.

In using this Tool, you expressly assume all risks associated with your use. Under no circumstances shall ASCE or its officers, directors, employees, members, affiliates, or agents be liable to you or any other person for any direct, indirect, special, incidental, or consequential damages arising from or related to your use of, or reliance on, the Tool or any information obtained therein. To the fullest extent permitted by law, you agree to release and hold harmless ASCE from any and all liability of any nature arising out of or resulting from any use of data provided by the ASCE Hazard Tool.